

Annual Environmental Report

2023



Castlemartyr

D0134-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CASTLEMARTYR WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CASTLEMARTYR WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CASTLEMARTYR WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CASTLEMARTYR WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO CASTLEMARTYR WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0134-01, Castlemartyr, in Cork in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Castlemartyr WWTP with a Plant Capacity PE of 2000, the treatment type is 2 - Secondary treatment .

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0500D0134SW001	Castlemartyr WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CASTLEMARTYR WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CASTLEMARTYR WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	12	703	409
BOD, 5 days with Inhibition (Carbonaceo mg/l	12	286	169
Suspended Solids mg/l	12	289	177
Hydraulic Capacity	N/A	775	504

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0500D0134SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	37	Pass
Suspended Solids mg/l	35	87.5	N/A	12	1	N/A	17	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	15	30	N/A	12	1	N/A	7.52	Pass
pH pH units	9	9	N/A	12	N/A	N/A	7.59	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.5	0.6	N/A	12	7	6	0.738	Fail
Ammonia-Total (as N) mg/l	0.5	1	N/A	12	9	9	8.15	Fail

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Refer to the incidents section of this report.

Significance of Results:

The WWTP is not in compliance with the ELV, as set out in the WDDL. The impact on receiving waters is assessed further in section 2.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0500D0134SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WDDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	196366, 73252	RS19W011000	No	No	No	No	Moderate
Downstream	196154, 72688	RS19W011040	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS19W011000	1.34	RS19W011040	2.20	1.50	57.7
Ammonia-Total (as N) mg/l	RS19W011000	0.054	RS19W011040	0.187	0.065	204.7
ortho-Phosphate (as P) - unspecified mg/l	RS19W011000	0.045	RS19W011040	0.051	0.035	19.1

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
AMPA ng/l	RS19W011000	141	RS19W011040	N/A	N/A	
Vanadium - filtered µg/l	RS19W011000	0.786	RS19W011040	N/A	N/A	
Thallium - filtered µg/l	RS19W011000	0.141	RS19W011040	N/A	N/A	
Total Hardness (as CaCO3) mg/l	RS19W011000	70	RS19W011040	N/A	N/A	
Alkalinity-total (as CaCO3) mg/l	RS19W011000	58	RS19W011040	N/A	N/A	
Temperature °C	RS19W011000	12	RS19W011040	13	N/A	
Conductivity @25°C µS/cm	RS19W011000	241	RS19W011040	N/A	N/A	
COD-Cr mg/l	RS19W011000	19	RS19W011040	17	N/A	
Chromium - filtered µg/l	RS19W011000	3.60	RS19W011040	N/A	N/A	
C10-C13 Chloroalkanes µg/l	RS19W011000	0.283	RS19W011040	N/A	N/A	
beta-Hexabromocyclododecane (HBCDD) µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
Cobalt - filtered µg/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Calculated Hardness (CaCO3) - Dissolved Components mg/l	RS19W011000	110	RS19W011040	N/A	N/A	
Benzo(a)pyrene ng/l	RS19W011000	0.752	RS19W011040	N/A	N/A	
Manganese - filtered µg/l	RS19W011000	7.11	RS19W011040	N/A	N/A	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Glyphosate ng/l	RS19W011000	172	RS19W011040	N/A	N/A	
Linuron ng/l	RS19W011000	3.54	RS19W011040	N/A	N/A	
Molybdenum - filtered µg/l	RS19W011000	3.71	RS19W011040	N/A	N/A	
Dissolved Oxygen mg/l	RS19W011000	11	RS19W011040	N/A	N/A	
Selenium - filtered µg/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Aluminium - filtered µg/l	RS19W011000	18	RS19W011040	N/A	N/A	
Atrazine ng/l	RS19W011000	1.41	RS19W011040	N/A	N/A	
True Colour mg/litre Pt Co	RS19W011000	17	RS19W011040	N/A	N/A	
Benzo(b)fluoranthene ng/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Cadmium - filtered µg/l	RS19W011000	0.014	RS19W011040	N/A	N/A	
Boron - filtered µg/l	RS19W011000	12	RS19W011040	N/A	N/A	
Di(2-ethylhexyl) phthalate (DEHP) µg/l	RS19W011000	0.141	RS19W011040	N/A	N/A	
Iron - filtered µg/l	RS19W011000	53	RS19W011040	N/A	N/A	
Nickel - filtered µg/l	RS19W011000	15	RS19W011040	N/A	N/A	
Potassium - filtered mg/l	RS19W011000	2.23	RS19W011040	N/A	N/A	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Terbutryn ng/l	RS19W011000	1.41	RS19W011040	N/A	N/A	
Uranium - filtered µg/l	RS19W011000	0.148	RS19W011040	N/A	N/A	
alpha-Hexabromocyclododecane (HBCDD) µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
Zinc - filtered µg/l	RS19W011000	4.25	RS19W011040	N/A	N/A	
Benzo(k)fluoranthene ng/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Chloride mg/l	RS19W011000	20	RS19W011040	N/A	N/A	
Barium - filtered µg/l	RS19W011000	7.63	RS19W011040	N/A	N/A	
Dicofol µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
Cypermethrin µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
Isoproturon ng/l	RS19W011000	1.41	RS19W011040	N/A	N/A	
Diuron ng/l	RS19W011000	3.54	RS19W011040	N/A	N/A	
Magnesium - filtered mg/l	RS19W011000	5.53	RS19W011040	N/A	N/A	
Benzo(g,h,i)perylene ng/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
pH pH units	RS19W011000	7.77	RS19W011040	7.79	N/A	
Sodium - filtered mg/l	RS19W011000	10	RS19W011040	N/A	N/A	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Dissolved Organic Carbon mg/l	RS19W011000	3.45	RS19W011040	N/A	N/A	
Suspended Solids mg/l	RS19W011000	27	RS19W011040	10	N/A	
Fluoride mg/l	RS19W011000	0.141	RS19W011040	N/A	N/A	
Arsenic - filtered µg/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Antimony - filtered µg/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
2,4-D ng/l	RS19W011000	4.02	RS19W011040	N/A	N/A	
Anthracene ng/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Total Oxidised Nitrogen (as N) mg/l	RS19W011000	5.37	RS19W011040	N/A	N/A	
Copper - filtered µg/l	RS19W011000	1.30	RS19W011040	N/A	N/A	
Calcium - filtered mg/l	RS19W011000	22	RS19W011040	N/A	N/A	
Bifenox µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
MCPA ng/l	RS19W011000	7.31	RS19W011040	N/A	N/A	
Dissolved Oxygen % Saturation	RS19W011000	101	RS19W011040	95	N/A	
Lead - filtered µg/l	RS19W011000	0.148	RS19W011040	N/A	N/A	
Beryllium - filtered µg/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
Mecoprop ng/l	RS19W011000	5.72	RS19W011040	N/A	N/A	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Fluoranthene ng/l	RS19W011000	0.752	RS19W011040	N/A	N/A	
Indeno(1,2,3-c,d)pyrene ng/l	RS19W011000	0.707	RS19W011040	N/A	N/A	
gamma-Hexabromocyclododecane µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
Mercury - filtered µg/l	RS19W011000	0.017	RS19W011040	N/A	N/A	
Perfluorooctane sulfonic acid (PFOS) µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	
Simazine ng/l	RS19W011000	1.41	RS19W011040	N/A	N/A	
Strontium - filtered µg/l	RS19W011000	50	RS19W011040	N/A	N/A	
Perfluorooctanoic acid (PFOA) µg/l	RS19W011000	N/A	RS19W011040	N/A	N/A	

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: ortho-Phosphate (as P) - unspecified mg/l, Ammonia-Total (as N) mg/l.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ammonia & Ortho Phosphate, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CASTLEMARTYR WWTP

2.1.4.1 Treatment Efficiency Report - Castlemartyr WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	N/A	N/A	N/A
TN	N/A	N/A	N/A
COD	76565	7010	91
cBOD	31623	1409	96
SS	33153	3204	90

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Castlemartyr WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Castlemartyr WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	1200
DWF to the Treatment Plant (m ³ /day)	400
Current Hydraulic Loading - annual max (m ³ /day)	775

Castlemartyr WWTP	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	504
Organic Capacity (PE) - As Constructed	2000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	1868
Organic Capacity (PE) - Remaining	132
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CASTLEMARTYR WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2023.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
Spillage	Plant or equipment breakdown at WWTP	No	Yes
Breach of ELV	WWTP upgrade required to meet ELV	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	2
Number of Incidents reported to the EPA via EDEN in 2023	2
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
SW002	196240,72903	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW003	196379,73199	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
D0134-SIP:01	Improvement works to ensure compliance with the emission limit values as set out in Schedule A: Discharges & Discharge Monitoring	C	31/12/2019	Yes	At Planning Stage	2027	

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
D0134-01-Priority Substances Assessment	Yes	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	Yes
List reason e.g. additional SWO identified	EPA Initiated Review
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	Yes
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 01/05/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

7 APPENDIX

There are no Appendices included