

# Annual Environmental Report

2023



Creeslough

D0534-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 CREESLOUGH WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - CREESLOUGH WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - CREESLOUGH WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CREESLOUGH WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO CREESLOUGH WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2023 AER

This Annual Environmental Report has been prepared for D0534-01, Creeslough, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Creeslough WWTP with a Plant Capacity PE of 300, the treatment type is 2 - Secondary treatment .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0534SW001	Creeslough WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 CREESLOUGH WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CREESLOUGH WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
pH pH units	6	8.00	7.63
BOD, 5 days with Inhibition (Carbonaceo mg/l	6	202	130
COD-Cr mg/l	6	489	324
ortho-Phosphate (as P) - unspecified mg/l	6	9.38	4.50
Suspended Solids mg/l	6	426	185
Ammonia-Total (as N) mg/l	6	90	41
Hydraulic Capacity	N/A	131	131

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0600D0534SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	6	1	N/A	69	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	6	1	N/A	22	Pass
<b>BOD, 5 days with Inhibition (Carbonaceo mg/l)</b>	25	50	N/A	6	N/A	N/A	9.50	Pass
<b>pH pH units</b>	9	9	N/A	6	N/A	N/A	7.43	Pass
<b>Ammonia-Total (as N) mg/l</b>	2	2.4	N/A	6	6	6	9.50	Fail
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1	1.2	N/A	6	5	3	1.84	Fail
<b>Enterococci (Intestinal) cfu/100ml</b>	N/A	N/A	N/A	2	N/A	N/A	33000	
<b>Conductivity @20°C µS/cm</b>	N/A	N/A	N/A	6	N/A	N/A	584	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>E. Coli MPN/100ml</b>	N/A	N/A	N/A	2	N/A	N/A	210650	
<b>Faecal coliforms cfu/100ml</b>	N/A	N/A	N/A	2	N/A	N/A	127600	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Refer to Incident Section of Report.

### Significance of Results:

The WWTP is non-compliant with the ELVs set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0600D0534SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	205359, 431675	RS38F010190	No	No	No	No	Moderate
Downstream	205467, 431677	RS38F010300	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS38F010190	1.83	RS38F010300	1.17	1.50	-44.4
Ammonia-Total (as N) mg/l	RS38F010190	0.027	RS38F010300	0.133	0.065	162.9
ortho-Phosphate (as P) - unspecified mg/l	RS38F010190	0.035	RS38F010300	0.046	0.035	30.8
pH pH units	RS38F010190	7.68	RS38F010300	7.42	N/A	
Temperature °C	RS38F010190	9.78	RS38F010300	9.75	N/A	
Faecal coliforms cfu/100ml	RS38F010190	70	RS38F010300	1498	N/A	
Dissolved Oxygen % Saturation	RS38F010190	98	RS38F010300	97	N/A	
Suspended Solids mg/l	RS38F010190	4.24	RS38F010300	5.54	N/A	



Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>Conductivity @20°C µS/cm</b>	RS38F010190	172	RS38F010300	189	N/A	
<b>E. Coli MPN/100ml</b>	RS38F010190	186	RS38F010300	1249	N/A	
<b>Enterococci (Intestinal) cfu/100ml</b>	RS38F010190	60	RS38F010300	255	N/A	

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N) mg/l, ortho-Phosphate (as P) - unspecified mg/l.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD mg/l, Ammonia (as N) mg/l, ortho-Phosphate (as P) - unspecified mg/l, concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CREESLOUGH WWTP

### 2.1.4.1 Treatment Efficiency Report - Creeslough WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>COD</b>	15563	3317	79
<b>TN</b>	N/A	N/A	N/A
<b>cBOD</b>	6259	456	93
<b>TP</b>	N/A	N/A	N/A
<b>SS</b>	8857	1047	88

Note: The above data is based on sample results for the number of dates reported

#### **2.1.4.2 Treatment Capacity Report Summary - Creeslough WWTP**

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

<b>Creeslough WWTP</b>	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	204
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	68
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	131.4
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	131.4
<b>Organic Capacity (PE) - As Constructed</b>	300
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	584
<b>Organic Capacity (PE) - Remaining</b>	0
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

### 2.1.5 SLUDGE / OTHER INPUTS - CREESLOUGH WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2023.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	Recurring (Y/N)	Closed (Y/N)
<b>Breach of ELV</b>	WWTP upgrade required to meet ELV	Yes	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2023	1
Number of Incidents reported to the EPA via EDEN in 2023	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2023 (No. of events)	Total volume discharged in 2023 (m3)	Monitoring Status
<b>SW002</b>	205389,431661	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much wastewater discharge by metered SWOs during the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	Unknown

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0534-SIP:01</b>	Improvement works including nutrient reduction to ensure compliance with the ELVs as set out in Schedule A: Discharges and Discharge Monitoring of this licence.	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period
<b>D0534-SIP:02</b>	Improvement works to ensure compliance with Condition 1.7	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Included in this AER
<b>D0534-01-Priority Substances Assessment</b>	Yes	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 23/10/2024

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Creslough AMBIENT MONITORING SUMMARY 2023

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	EPA Feature Coding Tool code	Receiving Waters Designation (Y/N)				WFD Status
			Bathing Water	Drinking Water	FWPM	Shellfish	
Upstream Monitoring Point	205359, 431675	RS38F010190	No	No	No	No	Moderate
Downstream Monitoring Point	205467, 431677	RS38F010300	No	No	No	No	Moderate

**Ambient Impact Assessment Table**

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS (Mean)	% EQS
BOD mg/l	RS38F010190	1.8	RS38F010300	1.1	1.5	-46%
Ammonia (as N) mg/l	RS38F010190	0.032	RS38F010300	0.133	0.065	155%
ortho-Phosphate (as P) - unspecified mg/l	RS38F010190	0.050	RS38F010300	0.058	0.035	22.8%

### Creeslough D0534-01 Ambient Monitoring Data

Entity Name	Station	Date	Ammonia (as N)	BOD	Conductivity @ 20°C	DO	E coli	Enterococci	Faecal Coliforms	Orthophosphate	pH	Suspended Solids	Temperature
Faymore	Creeslough - Upstream	24-Jan-23	<0.05	1	180	98.7	63	20	41	<0.05	7.3	<6	8.6
Faymore	Creeslough - Upstream	21-Mar-23	0.015	1	137	100.3	310	100	100	<0.05	7.2	<6	9.3
Faymore	Creeslough - Upstream	30-May-23	0.017	5	240	96.2	NT	NT	NT	<0.05	7.8	<6	10.5
Faymore	Creeslough - Upstream	25-Jul-23	0.048	1	184	95.7	NT	NT	NT	<0.05	8.5	<6	13.6
Faymore	Creeslough - Upstream	21-Sep-202	< 0.015	2	127	98				< 0.05	7.7	< 6	11.1
Faymore	Creeslough - Upstream	28-Nov-202	< 0.05	1	166	98.4				< 0.05	7.6	< 6	5.6
Faymore	Creeslough - Downstream	24-Jan-23	0.045	1	200	98	318	310	837	<0.05	7.2	<6	8.6
Faymore	Creeslough - Downstream	21-Mar-23	0.032	1	130	99.5	2180	200	2160	<0.05	7.3	<6	9
Faymore	Creeslough - Downstream	30-May-23	0.393	2	237	96.5	NT	NT	NT	0.1	7.6	<6	10.6
Faymore	Creeslough - Downstream	25-Jul-23	0.064	1	188	93.3	NT	NT	NT	<0.05	7.6	<6	13.6
Faymore	Creeslough - Downstream	21-Sep-202	< 0.015	1	138	98.4				< 0.05	7.6	12	11.1
Faymore	Creeslough - Downstream	28-Nov-202	0.252	1	240	97.2				< 0.05	7.2	< 6	5.6