

Annual Environmental Report

2018



Nenagh

D0027-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

1.1 TREATMENT SUMMARY

1.1.1 NENAGH NEW WWTP

1.2 ELV OVERVIEW

1.3 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMAND AND IMPACT SUMMARY

2.1 NENAGH NEW WWTP - TREATED DISCHARGE

2.1.1 INFLUENT SUMMARY - NENAGH NEW WWTP

2.1.2 EFFLUENT MONITORING SUMMARY - NENAGH NEW WWTP -

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -

2.1.4 OPERATIONAL REPORTS SUMMARY FOR NENAGH NEW WWTP

2.1.5 SLUDGE/OTHER INPUTS TO NENAGH NEW WWTP

2.1.6 SLUDGE REMOVAL NENAGH NEW WWTP

3 COMPLAINTS SUMMARY

3.1 REPORTED INCIDENTS SUMMARY

3.1.1 SUMMARY OF INCIDENTS

3.1.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0027-01, Nenagh, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Nenagh New WWTP with a Plant Capacity PE of 11000

The treatment process includes the following:

1.1.1 NENAGH NEW WWTP

| Treatment type | Yes / No | Details |
|-----------------------|----------|--|
| Preliminary Treatment | Yes | Automatic Screening and Grit Removal |
| Primary Treatment | No | |
| Secondary Treatment | Yes | Conventional Activated Sludge |
| Nutrient Removal | Yes | Chemical Dosing for Phosphorus removal |
| Tertiary Treatment | No | |

1.2 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

| Discharge Point Reference | Treatment Plant | Discharge Type | Compliance Status | Parameters failing if relevant |
|---------------------------|-----------------|----------------|-------------------|--------------------------------|
| TPEFF2800D0027SW001 | Nenagh New WWTP | Treated | Compliant | Not Applicable |

1.3 LICENCE SPECIFIC REPORTING INCLUDED IN AER

| Assessment / Report | Included in AER |
|---|-----------------|
| There is no Licence Specific Reports included in the AER. | |

2 TREATMENT PLANT PERFORMAND AND IMPACT SUMMARY

2.1 NENAGH NEW WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - NENAGH NEW WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

| Parameters | Number of Samples | Annual Max | Annual Mean |
|---|-------------------|------------|-------------|
| Suspended Solids mg/l | 13 | 1163 | 363.31 |
| BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l | 13 | 510 | 191.68 |
| COD-Cr mg/l | 13 | 1290 | 586.31 |
| Total Nitrogen mg/l | 13 | 53 | 21.63 |
| Total Phosphorus (as P) mg/l | 13 | 7.45 | 3.41 |
| Hydraulic Capacity | N/A | 20053 | 5697 |

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2800D0027SW002

| Parameter | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included Note 1 | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|---|-----------------------|---|---|--------------------------|-----------------------|--|-------------|--------------------------------|
| COD-Cr mg/l | 100 | 200 | 0 | 12 | 0 | 0 | 20.94 | Pass |
| Suspended Solids mg/l | 30 | 75 | 0 | 12 | 0 | 0 | 13.88 | Pass |
| Temperature °C | 25 | 0 | 0 | 12 | 0 | 0 | 12.48 | Pass |
| BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l | 20 | 40 | 0 | 12 | 0 | 0 | 4.71 | Pass |
| Ammonia-Total (as N) mg/l | 1.4 | 2.8 | 0 | 12 | 1 | 0 | 0.47 | Pass |
| Total Phosphorus (as P) mg/l | 1 | 1.2 | 0 | 12 | 0 | 0 | 0.19 | Pass |
| ortho-Phosphate (as P) - unspecified mg/l | 0.75 | 0.9 | 0 | 12 | 0 | 0 | 0.05 | Pass |
| Total Oxidised Nitrogen (as N) mg/l | 0 | 0 | 0 | 12 | 0 | 0 | 7.18 | |
| pH pH units | 0 | 0 | 0 | 12 | 0 | 0 | 7.38 | |

| Parameter | WWDL ELV (Schedule A) | ELV with Condition 2 Interpretation included Note 1 | Interim % reduction from influent concentration | Number of sample results | Number of exceedances | Number of with Condition 2 Interpretation included | Annual Mean | Overall Compliance (Pass/Fail) |
|-------------------------------|-----------------------|---|---|--------------------------|-----------------------|--|-------------|--------------------------------|
| Nitrite (as N) mg/l | 0 | 0 | 0 | 12 | 0 | 0 | 0.16 | |
| ortho-Phosphate (as PO4) mg/l | 0 | 0 | 0 | 1 | 0 | 0 | 0 | |
| Total Nitrogen mg/l | 0 | 0 | 0 | 12 | 0 | 0 | 9.03 | |
| Sulphate mg/l | 0 | 0 | 0 | 12 | 0 | 0 | 53.96 | |
| Nitrate (as N) mg/l | 0 | 0 | 0 | 12 | 0 | 0 | 7.01 | |

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

Cause of Exceedance(s):

Not Applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

| Ambient Monitoring Point from WWDL (or as agreed with EPA) | Irish Grid Reference | Code | Bathing Water | Drinking Water | FWPM | Shellfish | WFD Status |
|--|----------------------|---------------------|---------------|----------------|------|-----------|------------|
| Upstream | 187349, 179986 | TPEFF2800D0027SW001 | No | No | No | No | Moderate |
| Downstream | 187229, 180175 | TPEFF2800D0027SW001 | No | No | No | No | Moderate |

The results for ambient results and / or additional monitoring data sets are included in the **Appendix IW.Eims.AERReportPortal.Models.AppendixModel**

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS.

The discharge from the wastewater treatment plant do not have an observable impact on the water quality.

The discharge from the wastewater treatment plant do not have an observable negative impact on the Water Framework Directive status.

Other Potential cause of deterioration in water quality relevant to this area are: Upstream sources to be investigated

2.1.4 OPERATIONAL PERFORMANCE SUMMARY

2.1.4.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

| Parameter | Influent mass loading (kg/year) | Effluent mass emission (kg/year) | Efficiency (% reduction of influent load) | Comment |
|-----------|---------------------------------|----------------------------------|---|---------|
| TP | 0 | 373.96 | 95.08 | |
| cBOD | 0 | 9340.05 | 97.81 | |

| Parameter | Influent mass loading (kg/year) | Effluent mass emission (kg/year) | Efficiency (% reduction of influent load) | Comment |
|-----------|---------------------------------|----------------------------------|---|---------|
| SS | 0 | 27535.78 | 96.59 | |
| TN | 0 | 17921.47 | 62.75 | |
| COD | 0 | 41542.78 | 96.81 | |

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

| Nenagh New WWTP | |
|--|-------|
| Peak Hydraulic Capacity (m3/day) - As Constructed | 12960 |
| DWF to the Treatment Plant (m3/day) | 4320 |
| Current Hydraulic Loading - annual max (m3/day) | 20053 |
| Average Hydraulic loading to the Treatment Plant (m3/day) | 5697 |
| Organic Capacity (PE) - As Constructed | 11000 |
| Organic Capacity (PE) - Collected Load (peak week) | 12628 |
| Organic Capacity (PE) - Remaining | 0 |
| Will the capacity be exceeded in the next three years? (Yes/No) | Yes |

2.1.5 SLUDGE / OTHER INPUTS

'Other inputs' to the waste water treatment plant are summarised in table below

| Input type | Quantity | Unit | P.E. | % of load to WWTP | Included in Influent Monitoring (Y/N)? | Is there a leachate/sludge acceptance procedure for the WWTP? | Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N) |
|-------------------|----------|-----------------|------|-------------------|--|---|--|
| Waterworks Sludge | 422 | Weight (Tonnes) | 13 | 0.02 | No | Yes | No |
| Waterworks Sludge | 2575 | Weight (Tonnes) | 77 | 0.13 | No | Yes | No |
| Waterworks Sludge | 4477 | Weight (Tonnes) | 134 | 0.22 | No | Yes | No |

2.1.6 SLUDGE REMOVAL

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

| Treatment Plant | Sludge type | Quantity | Unit | % Dry Solids | Destination |
|-----------------|-------------|----------|-----------------|--------------|---|
| Nenagh New WWTP | Cake Sludge | 1406.6 | Weight (Tonnes) | 15.17 | Bunlicky WWTP Limerick D0013-01 |
| Nenagh New WWTP | Cake Sludge | 893.22 | Weight (Tonnes) | 15.17 | H&L Environmental Services Ltd. WFP-T-12-003-02 |
| Nenagh New WWTP | Cake Sludge | 83.88 | Weight (Tonnes) | 20 | Acorn Recycling LTD. W0249-01 |

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

| Number of Complaints | Nature of Complaint | Number Open Complaints | Number Closed Complaints |
|----------------------|---------------------|------------------------|--------------------------|
| 12 | Blocked Sewer | 4 | 8 |

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

| Incident Type | Cause | No. of incident occurrences | Recurring (Y/N) | Closed (Y/N) |
|----------------------|----------------------------------|-----------------------------|-----------------|--------------|
| Uncontrolled release | EO caused by ragging or blocking | 1 | No | Yes |

3.2.2 SUMMARY OF OVERALL INCIDENTS

| Question | Answer |
|--|--------|
| Number of Incidents in 2018 | 1 |
| Number of Incidents reported to the EPA via EDEN in 2018 | 1 |
| Explanation of any discrepancies between the two numbers above | |

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

| WWDL Name / Code for Storm Water Overflow | Irish Grid Ref. | Included in Schedule A4 of the WWDL | Significance of the overflow(High / Medium / Low) | Assessed against DoEHLG Criteria | No. of times activated in 2018 (No. of events) | Total volume discharged in 2018 (m3) | Monitoring Status |
|---|-----------------|-------------------------------------|---|----------------------------------|--|--------------------------------------|-------------------|
| SW3 | 186851, 179064 | Yes | Unknown | Not yet Assessed | | | Not Monitored |
| SW4 | 186853, 179069 | Yes | Unknown | Not yet Assessed | | | Not Monitored |
| SW5 | 186703, 178889 | Yes | Unknown | Not yet Assessed | | | Not Monitored |

| SWO Summary | |
|--|----|
| How much sewage was discharged via SWOs in the agglomeration in the year (m3)? | |
| Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements? | No |
| The SWO Assessment included the requirements of relevant of WWDL schedules? | No |

SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Description | Licence Schedule | Licence Completion Date | Date Expired? (N/NAY) | Status of Works | Timeframe for Completing the Work | Comments |
|---|--|------------------|-------------------------|-----------------------|-----------------|-----------------------------------|--|
| D0027-SIP:01 | Upgrade of sewer network to ensure SWOs comply with DoE criteria | C | | No | Not Started | | The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis |
| D0027-SIP:02 | Waste water sewer network improvements | C | | No | Not Started | | The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis |

| Specified Improvement Programmes (under Schedule A and C of WWDL) | Description | Licence Schedule | Licence Completion Date | Date Expired? (N/NAY) | Status of Works | Timeframe for Completing the Work | Comments |
|---|---------------------------|------------------|-------------------------|-----------------------|-----------------|-----------------------------------|--|
| D0027-SIP:03 | WWTP upgrade/improvements | C | 01/01/2015 | Yes | Not Started | | The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis |

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

| Improvement Identifier | Improvement Description | Improvement Source | Expected Completion Date | Comments |
|--|-------------------------|--------------------|--------------------------|----------|
| There are no Improvements Programme for this Agglomeration. | | | | |

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

| Licence Specific Report | Required by licence | Year included in AER | Included in this AER | Reference to relevant section of AER |
|--|---------------------|----------------------|----------------------|--------------------------------------|
| There is no Licence Specific Report Required in this AER Annual Review. | | | | |

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

| Parameter | Answer |
|--|--|
| Does the AER include an Executive Summary? | Yes |
| Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)? | Yes |
| Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence? | Yes |
| List reason e.g. additional SWO identified | Secondary discharge has been discontinued. |
| Is there a need to request/advise the EPA of any modifications to the existing WWDL? | No |
| List reason e.g. changes to monitoring requirements | |
| Have these processes commenced? | No |
| Are all outstanding reports and assessments from previous AERs included as an appendix to this AER | No |

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 29/04/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

| |
|---|
| Appendix |
| Appendix 7.1 - Ambient monitoring summary |

Nenagh Upstream 2018

| Category | River | Station | Station Reference | Easting | Northing | Sample Reference | Sample Date | Analyst Conclusion | Parameter | Ammonia N | BOD | D.O. | D.O. % Saturation | Ortho-Phosphate P | pH | Total Nitrogen N | Coliform Bacteria | E Coli |
|--------------------|--------|------------------------|-------------------|---------|----------|------------------|--------------|--------------------|-----------|-----------|-------|-------|-------------------|-------------------|------|------------------|-------------------|--------|
| | | | | | | | | | mg/l | mg/l | mg/l | % O2 | mg/l | pH units | mg/l | MPN/100mls | MPN/100mls | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0003 | 18-Jan-2018 | - | 0.029 | 2.3 | 10.87 | 92 | 0.031 | 7.73 | 1.7 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0067 | 8-Feb-2018 | - | 0.026 | 1.9 | 10.74 | 101 | 0.015 | 7.99 | 3 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0116 | 8-Mar-2018 | - | < 0.01 | 1.9 | 11.58 | 94.1 | 0.014 | 8.03 | 2.4 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0166 | 5-Apr-2018 | - | < 0.01 | 2.2 | 11.22 | 93.1 | 0.034 | 7.94 | 2.1 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0229 | 22-May-2018 | - | 0.058 | 3 | 10.43 | 92.7 | 0.037 | 7.87 | 2.9 | 19600 | 13700 | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0251 | 7-June-2018 | - | 1.47 | 6.7 | 7.8 | 80.9 | 0.144 | 7.8 | 4.4 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0306 | 10-July-2018 | - | 0.027 | 2.1 | 8.92 | 93.4 | 0.03 | 7.94 | 3.3 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0350 | 2-Aug-2018 | - | 0.043 | 2.7 | 8.27 | 86.5 | 0.023 | 7.83 | 5.6 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0413 | 13-Sep-2018 | - | 0.018 | 1.1 | 9.54 | 90.8 | 0.014 | 7.79 | 5.9 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0469 | 4-Oct-2018 | - | 0.029 | <1 | 9.45 | 91.7 | 0.09 | 7.89 | 3.3 | 3000 | 150 | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0524 | 15-Nov-2018 | - | 0.031 | 2 | 9.88 | 93.9 | 0.033 | 7.84 | 3.1 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0541 | 22-Nov-2018 | - | 0.018 | 2.3 | 11.08 | 102.1 | 0.022 | 7.97 | 3.2 | | | |
| Ambient Monitoring | Nenagh | Upstream @ Nenagh WWTP | RS25N010605 | 187349 | 179986 | 1855WW0559 | 6-Dec-2018 | - | 0.014 | 1.3 | 10.3 | 94.7 | 0.019 | 7.77 | 4 | | | |

Nenagh Downstream 2018

| Category | River | Station | Station Reference | Easting | Northing | Sample Reference | Sample Date | Analyst Conclusion | Parameter | Ammonia N | BOD | D.O. | D.O. % Saturation | Ortho-Phosphate P | pH | Total Nitrogen N | Coliform Bacteria | E Coli |
|--------------------|--------|--------------------------|-------------------|---------|----------|------------------|--------------|--------------------|-----------|-----------|-------|-------|-------------------|-------------------|------|------------------|-------------------|--------|
| | | | | | | | | | mg/l | mg/l | mg/l | % O2 | mg/l | pH units | mg/l | MPN/100mls | MPN/100mls | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0004 | 18-Jan-2018 | - | 0.039 | 2 | 11.04 | 91.6 | 0.042 | 7.72 | 1.9 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0068 | 8-Feb-2018 | - | 0.026 | 1.9 | 10.55 | 100.3 | 0.016 | 7.88 | 3.4 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0117 | 8-Mar-2018 | - | 0.014 | 2 | 11.5 | 94 | 0.015 | 8.01 | 2.6 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0167 | 5-Apr-2018 | - | < 0.01 | 2.1 | 10.73 | 91.6 | 0.025 | 7.9 | 2.4 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0230 | 22-May-2018 | - | 0.07 | 2.8 | 10.76 | 92.8 | 0.031 | 7.82 | 3 | 39700 | 16300 | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0252 | 7-June-2018 | - | 1.62 | 6.5 | 7.31 | 76.5 | 0.153 | 7.8 | 5.3 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0307 | 10-July-2018 | - | 0.024 | 2.3 | 8.96 | 94.4 | 0.031 | 7.92 | 5.6 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0351 | 2-Aug-2018 | - | 0.084 | 2.2 | 7.88 | 82.5 | 0.022 | 7.7 | 6 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0414 | 13-Sep-2018 | - | 0.021 | 2.4 | 9.11 | 87.2 | 0.015 | 7.71 | 8.1 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0470 | 4-Oct-2018 | - | 0.119 | <1 | 9.66 | 94.4 | 0.087 | 7.85 | 4.3 | 34350 | 3850 | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0525 | 15-Nov-2018 | - | 0.028 | 2.8 | 10.31 | 95.4 | 0.027 | 7.76 | 3 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0542 | 22-Nov-2018 | - | < 0.01 | 2.5 | 11.18 | 103.8 | 0.021 | 7.94 | 3.5 | | | |
| Ambient Monitoring | Nenagh | Downstream @ Nenagh WWTP | RS25N010620 | 187230 | 180176 | 1855WW0560 | 6-Dec-2018 | - | 0.012 | 1.6 | 9.88 | 91.8 | 0.049 | 7.71 | 4.1 | | | |