

Annual Environmental Report

2018



Enniscrone

D0102-01

TABLE OF CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
 - 1.2.1 ENNISCRONE WWTP
- 1.3 ELV OVERVIEW
 - 1.3.1 ENNISCRONE WWTP
- 1.4 SLUDGE REMOVAL

2 MONITORING REPORTS SUMMARY

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
 - 2.1.1 INFLUENT MONITORING SUMMARY - ENNISCRONE WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
 - 2.2.1 EFFLUENT MONITORING SUMMARY - ENNISCRONE WWTP
- 2.3 AMBIENT MONITORING SUMMARY
 - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - ENNISCRONE WWTP
 - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - ENNISCRONE WWTP

3 OPERATIONAL REPORTS SUMMARY

- 3.1 TREATMENT EFFICIENCY REPORT
 - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - ENNISCRONE WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
 - 3.4.1 SUMMARY OF INCIDENTS
 - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION
 - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

5 LICENCE SPECIFIC REPORTS

5.1 PRIORITY SUBSTANCES ASSESSMENT

5.2 TOXICITY OF FINAL EFFLUENT

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

6.2 DECLARATION BY IRISH WATER

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0102-01, Enniscrone, in Sligo in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
No licence specific reports included in the AER	NA

1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant Enniscrone WWTP with a Plant Capacity PE of 5000. The treatment process includes the following:

1.2.1 Enniscrone WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	inlet screening and grit removal
Primary Treatment	Yes	fine bubble diffused aeration tanks (2 nr)
Secondary Treatment	Yes	final clarifiers (2 nr)
Nutrient Removal	No	
Tertiary Treatment	No	

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

1.3 ELV Overview

1.3.1 Enniscrone WWTP

Compliance Status	
Were all parameters compliant for Enniscrone WWTP treatment plant	No
Where noncompliant see table 2.2.1 for details of parameters	

1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
Enniscrone WWTP	Cake Sludge	278	Weight (Tonnes)	16.8	D0014-01 (Sligo WwTP)

Annual Statement of Measures

There were no major capital or operational changes undertaken at Enniscrone WWTP.

2 MONITORING REPORTS SUMMARY

2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

2.1.1 Influent Monitoring Summary - Enniscrone WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
Total Nitrogen mg/l	20	83.09	25.2
Suspended Solids mg/l	20	1100	218.21
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	20	843	141.93
Total Phosphorus (as P) mg/l	20	17.1	3.39
COD-Cr mg/l	20	2680	369.25
Hydraulic Capacity	0	2362	788

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.2 Discharges from the agglomeration

2.2.1 Effluent Monitoring Summary - Enniscrone WWTP

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
pH pH units	0	0	0	8	0	0	7.73	Pass
Ammonia-Total (as N) mg/l	10	20	0	20	1	0	2.09	Pass
ortho-Phosphate (as P) - unspecified mg/l	0	0	0	1	0	0	0	Pass
Conductivity 20 C μ S/cm	0	0	0	1	0	0	0	Pass
Total Oxidised Nitrogen (as N) mg/l	15	18	0	20	4	2	8.56	Fail
Total Phosphorus (as P) mg/l	0	0	0	13	0	0	0.67	Pass
Total Nitrogen mg/l	0	0	0	1	0	0	0	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	0	20	0	0	3.78	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	0	20	0	0	29.57	Pass
Suspended Solids mg/l	35	87.5	0	20	0	0	9.23	Pass
Temperature °C	25	0	0	8	0	0	6.15	Pass

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

Cause of Exceedance(s):

Plant not performing to optimum, monitoring ongoing

Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence.

There were four exceedances in relation to the total oxidized nitrogen ELV, two of which were above the Condition 2 ELV.

The impact on receiving water is assessed further in Section 2.3.

2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

2.3.1 Ambient Monitoring Report Summary - Enniscrone WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Downstream	128435, 331268	CW22005295MY2010	No	No	No	No	Good

2.3.2 Ambient Monitoring Parameter Summary - Enniscrone WWTP

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS.

The discharge from the wastewater treatment plant do not have an observable impact on the water quality.

The discharge from the wastewater treatment plant do not have an observable negative impact on the Water Framework Directive status.

3 OPERATIONAL REPORTS SUMMARY

3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

3.1.1 Treatment Efficiency Report Summary - Enniscrone WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
COD	100792.51	6267.03	93.78	
SS	59564.15	1955.91	96.72	
cBOD	38742.07	801.35	97.93	
TP	925.75	143.45	84.5	
TN	6879.69	0	100	

Note: The above data is based on sample results for the number of dates reported

3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Enniscrone WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	3369
DWF to the Treatment Plant (m ³ /day)	1123
Current Hydraulic Loading - annual max (m ³ /day)	2362
Average Hydraulic loading to the Treatment Plant (m ³ /day)	788
Organic Capacity (PE) - As Constructed	5000
Organic Capacity (PE) - Collected Load (peak week)	3293
Organic Capacity (PE) - Remaining	1707
Will the capacity be exceeded in the next three years? (Yes/No)	No

3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There is no Complaint data included in the AER.			

3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Non-compliance	WWTP not designed for N removal	2	No	No

3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	2
Number of Incidents reported to the EPA via EDEN in 2018	2
Explanation of any discrepancies between the two numbers above	exceedance of Ammonia (12.01 mg/L on 15/Mar) not reported

3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Domestic /Septic Tank Sludge	132	Volume (m ³)		0.05	No	Yes	No
Domestic /Septic Tank Sludge	10	Volume (m ³)		0	No	Yes	No
Domestic /Septic Tank Sludge	2.19	Volume (m ³)		0.02	No	Yes	No

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m ³)	Monitoring Status
SW002	128488, 330962	Yes	Medium	Meeting	50	-	Monitored
SW003	128359, 329720	Yes	Medium	Meeting	0	-	Not Monitored
SW004	128605, 331217	Yes	Medium	Meeting	0	-	Not Monitored

4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m ³)?	7363
Is each SWO identified as non meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / charges to Schedule C3 and A4 under Condition 1.7?	No

4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
There are no Specified Improvement Programmes for this Agglomeration.						

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
There are no Improvement Programmes for this Agglomeration.				

4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table".

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.1.1 Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER (e.g. Appendix X).
Priority Substances Assessment	Yes	2012	No	
Toxicity of Final Effluent	Yes	2012	No	

6 CERTIFICATION AND SIGN OFF

6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	-
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	-
Have these processes commenced?	-
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:

Date: 28/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

In the appendix include all the detailed or site specific reports that are relevant to the AER. Reports omitted from previous AERs should also be appended here.

Appendix

Appendix 7.1 - Ambient monitoring summary

Data/Statistics - 2018

Entity	Station	Station Code	Sample Reason	Sample Date	Ammonia N mg/l	BOD, 5 days w mg/l	Chlorophyll mg/m3	Chlorophyll µg/l	Dissolved Inorganic Nitrogen DIN mg/l	Dissolved Oxygen mg/l
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	21/02/2018		1	10.47		0.2	10.7
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	28/03/2018	0.2	1			0.2	10.1
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	09/04/2018	0.404	1.9	1.17		0.5	11
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	02/05/2018						
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	02/05/2018	0.429	1.8		3.4	0.3	11
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	06/06/2018						
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	06/06/2018	0.011	1		2.2	0.256	10
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	03/07/2018	0.347	2		29.6	0.4	9
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	03/07/2018						
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	01/08/2018						
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	01/08/2018	0.256	1.6		5.4	0.5	10
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	14/09/2018	0.393	1		3.2	0.5	9
Kilalla Bay	Downstream Enniscrone WwTP	CW22005295MY2010	Compliance	05/10/2018	0.4	1.3		7.3	0.4	12
Average					0.305	1.4	5.82	8.51666667	0.3617778	10.31111111

E Coli MPN/100 mls	Enterococci cfu/100mls	Faecal Coliforms no./100mls	Nitrate N mg/l	Nitrite N mg/l	Nitrite NO2 mg/l	pH pH units	Temperature Degrees C	Total Oxidised Nitrogen N mg/l
			0.15	0.005		7.98	8.3	0.1
			0.15			8.27	10.3	0.1
31	16	130				7.9	9.8	0.15
			0.15		0.005	8.1	9.8	0.15
	60	900						
			0.23		0.005	8.2	16.9	0.22
			0.15		0.005	8.3	25.4	0.15
29	35	35						
2	3	7						
			0.15		0.005	8.2	15.2	0.15
			0.15		0.005	8.2	12.7	0.15
			0.15		0.006	8.1	11.6	0.15

20.66667 28.5 268 0.1614286 0.005 0.005166667 8.138889 13.33333333 0.146666667