

Annual Environmental Report

2018



Fethard

D0164-01

TABLE OF CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
 - 1.2.1 FETHARD WWTP
- 1.3 ELV OVERVIEW
 - 1.3.1 FETHARD WWTP
- 1.4 SLUDGE REMOVAL

2 MONITORING REPORTS SUMMARY

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
 - 2.1.1 INFLUENT MONITORING SUMMARY - FETHARD WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
 - 2.2.1 EFFLUENT MONITORING SUMMARY - FETHARD WWTP
- 2.3 AMBIENT MONITORING SUMMARY
 - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - FETHARD WWTP
 - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - FETHARD WWTP

3 OPERATIONAL REPORTS SUMMARY

- 3.1 TREATMENT EFFICIENCY REPORT
 - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - FETHARD WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
 - 3.4.1 SUMMARY OF INCIDENTS
 - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION
 - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

5 LICENCE SPECIFIC REPORTS

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

6.2 DECLARATION BY IRISH WATER

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0164-01, Fethard, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
There is no Licence Specific Reports included in the AER.	

1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant Fethard WWTP with a Plant Capacity PE of 3000. The treatment process includes the following:

1.2.1 Fethard WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	Screening / grit removal
Primary Treatment	Yes	Primary settlement / inlet sump
Secondary Treatment	Yes	Activated sludge process
Nutrient Removal	Yes	Phosphorus removal
Tertiary Treatment	No	

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

1.3 ELV Overview

1.3.1 Fethard WWTP

Compliance Status	
Were all parameters compliant for Fethard WWTP treatment plant	Yes
Where noncompliant see table 2.2.1 for details of parameters	

1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
Fethard WWTP	Cake Sludge	311	Weight (Tonnes)	20	Clonmel Sludge Dryer
Fethard WWTP	Cake Sludge	13.94	Weight (Tonnes)	20	Molaisin Composting

Annual Statement of Measures

None

2 MONITORING REPORTS SUMMARY

2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

2.1.1 Influent Monitoring Summary - Fethard WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids	12	338	85.75
BOD, 5 days with Inhibition (Carbonaceous BOD)	12	460	135.73
COD-Cr	12	856	256.13
Total Nitrogen	12	59.8	25.16
Total Phosphorus (as P)	12	15.91	4.37
Hydraulic Capacity	0	3794	1256

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.2 Discharges from the agglomeration

2.2.1 Effluent Monitoring Summary - Fethard WWTP

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedences	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
pH	0	0	0	12	0	0	7.77	Pass
COD-Cr	125	250	0	12	0	0	8.9	Pass
ortho-Phosphate (as P) - unspecified	0	0	0	12	0	0	0.14	Pass
Total Nitrogen	0	0	0	12	0	0	5.78	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD)	25	50	0	12	0	0	1	Pass
Total Phosphorus (as P)	0	0	0	12	0	0	0.18	Pass
Suspended Solids	35	87.5	0	12	0	0	1.5	Pass
Ammonia-Total (as N)	0	0	0	12	0	0	0.14	Pass

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

Cause of Exceedance(s):

Not Applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

2.3.1 Ambient Monitoring Report Summary - Fethard WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	221645, 134803	TPEFF2900D0164SW001	No	No	No	No	Good
Downstream	221747, 134621	TPEFF2900D0164SW001	No	No	No	No	Good

2.3.2 Ambient Monitoring Parameter Summary - Fethard WWTP

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS.

The discharge from the wastewater treatment plant do not have an observable impact on the water quality.

The discharge from the wastewater treatment plant do not have an observable negative impact on the Water Framework Directive status.

3 OPERATIONAL REPORTS SUMMARY

3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

3.1.1 Treatment Efficiency Report Summary - Fethard WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
TN	10046.05	2309.85	77.01	
cBOD	54199.12	399.31	99.26	
SS	34242.75	598.97	98.25	
TP	1743.35	70.67	95.95	
COD	102273.97	3553.69	96.53	

Note: The above data is based on sample results for the number of dates reported

3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Fethard WWTP	
Peak Hydraulic Capacity (m3/day) - As Constructed	2250

Fethard WWTP	
DWF to the Treatment Plant (m3/day)	750
Current Hydraulic Loading - annual max (m3/day)	3794
Average Hydraulic loading to the Treatment Plant (m3/day)	1256
Organic Capacity (PE) - As Constructed	3000
Organic Capacity (PE) - Collected Load (peak week)	3461
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
4	Blocked Sewer	1	3

3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
There is no Incident data included in the AER.				

3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	0
Number of Incidents reported to the EPA via EDEN in 2018	0
Explanation of any discrepancies between the two numbers above	

3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)? ³	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP??(Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

No Appendix Included

4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m3)	Monitoring Status
TPEFF2900D0164SW002	221483, 135071	Yes	Low	Meeting			Not Monitored
TPEFF2900D0164SW003	221069, 134888	Yes	Low	Meeting			Not Monitored
TPEFF2900D0164SW004	221067, 134885	Yes	Low	Meeting			Not Monitored
TPEFF2900D0164SW005	221639, 134755	Yes	Low	Meeting			Not Monitored
TPEFF2900D0164SW006	221652, 134738	Yes	Low	Meeting			Not Monitored

4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	
Is each SWO identified as non meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs / charges to Schedule C3 and A4 under Condition 1.7?	No

4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
Carry out improvement works including nutrient reduction to ensure compliance with the emission limit values for orthophosphate and ammonia .	C	31/12/2019	No	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis
Carry out improvement works to increase the organic and hydraulic treatment capacity of the plant to ensure compliance with Condition 1.7	C	31/12/2019	No	Not Started		The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
Complete improvements to comply with ELVs specified in Schedule A. Implement, requirements in accordance with Condition 5.6.1.	C	31/12/2019	No	Not Started		The Condition 5 Assessment will be completed by Q1 2019

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table".

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER (e.g. Appendix X).
There is no Licence Specific Report Required in this AER Annual Review.				

6 CERTIFICATION AND SIGN OFF

6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 09/04/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

In the appendix include all the detailed or site specific reports that are relevant to the AER. Reports omitted from previous AERs should also be appended here.

Appendix

Appendix 7.1 - Ambient monitoring summary

Fethard Ambient Monitoring Data 2018

Parameter	Ammonia N	Biological Oxyg	COD Chemical	Dissolved Oxyg	Ortho-Phospha	pH	Suspended Soli	Temperature
Max.	--	--	--	--	--	--	--	--
Min.	--	--	--	--	--	--	--	--
Test Method	--	--	--	--	--	--	--	--

Category	Entity	Station	Station Reference	Easting	Northing	Sample Refere	Sample Date	Analyst Conclus	mg/l	mg/l	mg/l	mg/l	mg/l	pH units	mg/l	Degrees C
Ambient Monitoring	Clashawley	Downstream @ Fethard WWTP	RS16C010470	221747	134621	18550574	17-Apr-2018	-	0.4	3			0.14	8	31	
Ambient Monitoring	Clashawley	Upstream @ Fethard WWTP	RS16C010460	221645	134803	18550573	17-Apr-2018	-	0.04	2			0.05	7.3	8	
Ambient Monitoring	Clashawley	Upstream @ Fethard WWTP	RS16C010460	221645	134803	18550689	9-May-2018	-	0.06	0.7	6	9.69	0.007	8.1		10.1
Ambient Monitoring	Clashawley	Downstream @ Fethard WWTP	RS16C010470	221747	134621	18550690	9-May-2018	-	0.05	0.75	5	9.98	0.005	8.1		10.6
Ambient Monitoring	Clashawley	Upstream @ Fethard WWTP	RS16C010460	221645	134803	18550760	29-May-2018	-	0.06	2		9.81	0.04	8.2	6	19.1
Ambient Monitoring	Clashawley	Downstream @ Fethard WWTP	RS16C010470	221747	134621	18550761	29-May-2018	-	0.07	1		9.63	0.03	8.1	< 5	19.4
Ambient Monitoring	Clashawley	Upstream @ Fethard WWTP	RS16C010460	221645	134803	18550945	11-July-2018	-	0.06	1.46		12.7	0.023	8.1	1	22
Ambient Monitoring	Clashawley	Downstream @ Fethard WWTP	RS16C010470	221747	134621	18550946	11-July-2018	-	0.01	0.09		10.4	0.024	7.7	1	17
Ambient Monitoring	Clashawley	Downstream @ Fethard WWTP	RS16C010470	221747	134621	18551212	12-Sep-2018	-	0.17	4		8.56	0.06	8.12	18	17.1
Ambient Monitoring	Clashawley	Upstream @ Fethard WWTP	RS16C010460	221645	134803	18551211	12-Sep-2018	-	0.19	6		8.53	< 0.02	8	34	17.6
Ambient Monitoring	Clashawley	Downstream @ Fethard WWTP	RS16C010470	221747	134621	18551438	15-Oct-2018	-	0.17	< 1	< 5	5.21	0.04	7.58	< 3	12.7
Ambient Monitoring	Clashawley	Upstream @ Fethard WWTP	RS16C010460	221645	134803	18551437	15-Oct-2018	-	0.18	2	< 5	9.33	0.05	8.22	< 3	11.8