

# Annual Environmental Report

2019



Carrick-On-Suir

D0148-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 CARRICK-ON-SUIR WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - CARRICK-ON-SUIR WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - CARRICK-ON-SUIR WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CARRICK-ON-SUIR WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO CARRICK-ON-SUIR WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2019 AER

This Annual Environmental Report has been prepared for D0148-01, Carrick-On-Suir, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no Capital works or any other Operational Improvements in this reporting period.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CARRICK-ON-SUIR WWTP with a Plant Capacity PE of 11000, the treatment type is 3NP - Tertiary N&P removal

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2900D0148SW001	CARRICK-ON-SUIR WWTP	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
<b>There are no Licence Specific Reports included in the AER.</b>	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 CARRICK-ON-SUIR WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - CARRICK-ON-SUIR WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	12	210	94.69
<b>Total Phosphorus (as P) mg/l</b>	12	5.2	2.31
<b>COD-Cr mg/l</b>	12	520	224.55
<b>Total Nitrogen mg/l</b>	12	38.8	21.74
<b>Suspended Solids mg/l</b>	12	268	115.19
<b>Hydraulic Capacity</b>	N/A	8098	3125

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2900D0148SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	N/A	N/A	12.68	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	12	N/A	N/A	4.13	Pass
<b>BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l</b>	15	30	N/A	12	N/A	N/A	3.11	Pass
<b>Total Nitrogen mg/l</b>	15	18	N/A	24	N/A	N/A	9	Pass
<b>pH pH units</b>	9	9	N/A	12	N/A	N/A	7.66	Pass
<b>Total Phosphorus (as P) mg/l</b>	5	6	N/A	12	N/A	N/A	0.24	Pass
<b>Ammonia-Total (as N) mg/l</b>	5	6	N/A	12	N/A	N/A	0.29	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1.5	1.8	N/A	12	N/A	N/A	0.14	Pass

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

## Cause of Exceedance(s):

Not applicable

## Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

### 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2900D0148SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	242120, 121370	RS16S022950	No	No	Yes	No	Poor
Downstream	242429, 121346	RS16S022960	No	No	Yes	No	Poor

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	U/S Location	U/S Annual Mean	D/S Location	D/S Annual Mean	Difference	EQS	% of EQS
Ammonia-Total (as N) mg/l	RS16S022950	0.033	Not Accessible	N/A	N/A	0.065	
BOD - 5 days (Total) mg/l	RS16S022950	1.509	Not Accessible	N/A	N/A	1.500	
COD-Cr mg/l	RS16S022950	12.000	Not Accessible	N/A	N/A		
Dissolved Oxygen % O2	RS16S022950	100.460	Not Accessible	N/A	N/A		

Parameter Name	U/S Location	U/S Annual Mean	D/S Location	D/S Annual Mean	Difference	EQS	% of EQS
Dissolved Oxygen mg/l	RS16S022950	10.888	Not Accessible	N/A	N/A		
ortho-Phosphate (as P) - unspecified mg/l	RS16S022950	0.068	Not Accessible	N/A	N/A	0.035	
pH pH units	RS16S022950	8.435	Not Accessible	N/A	N/A		
Temperature °C	RS16S022950	12.382	Not Accessible	N/A	N/A		
Total Nitrogen mg/l	RS16S022950	3.045	Not Accessible	N/A	N/A		
Total Phosphorus (as P) mg/l	RS16S022950	0.148	Not Accessible	N/A	N/A		

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results not meet the required EQS upstream of the primary discharge. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CARRICK-ON-SUIR WWTP

### 2.1.4.1 Treatment Efficiency Report - CARRICK-ON-SUIR WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	2447	258	89
COD	237805	13433	94



Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>cBOD</b>	100278	3289	97
<b>TN</b>	23023	9183	60
<b>SS</b>	121985	4369	96

Note: The above data is based on sample results for the number of dates reported

#### 2.1.4.2 Treatment Capacity Report Summary - CARRICK-ON-SUIR WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CARRICK-ON-SUIR WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	7518
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	2506
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	8098
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	3125
<b>Organic Capacity (PE) - As Constructed</b>	11000
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	7197
<b>Organic Capacity (PE) - Remaining</b>	3803
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - CARRICK-ON-SUIR WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>Domestic /Septic Tank Sludge</b>	5110	Volume (m3)	1000	2	Yes	Yes	Yes
<b>Landfill Leachate (delivered by tanker)</b>	990	Volume (m3)		2	Yes	Yes	Yes

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
30	Blocked Sewer	0	30

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>There were no reportable incidents in 2019.</b>				

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2019	0
Number of Incidents reported to the EPA via EDEN in 2019	0
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
<b>SWO05</b>	242250, 122480	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
<b>SWO05</b>	239570, 121820	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
<b>SWO07</b>	241722, 121565	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
<b>SWO02</b>	240182, 121435	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
<b>SWO03</b>	240790, 121820	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
<b>SWO04</b>	239680, 121710	Yes	Low	Meeting	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2019 (No. of events)	Total volume discharged in 2019 (m3)	Monitoring Status
TBC	242257, 121343	No	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0148-SIP:02</b>	Cessation or upgrade of storm water overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows' (1995) - SW003	C	31/12/2020	No	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri
<b>D0148-SIP:04</b>	Cessation or upgrade of storm water overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows' (1995) - SW005	C	31/12/2020	No	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri
<b>D0148-SIP:05</b>	Cessation or upgrade of storm water overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows' (1995) - SW006	C	31/12/2020	No	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri
<b>D0148-SIP:06</b>	Cessation or upgrade of storm water overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows' (1995) - SW007	C	31/12/2020	No	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0148-SIP:01</b>	Cessation or upgrade of storm water overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows' (1995) - SW002	C	31/12/2020	No	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri
<b>D0148-SIP:03</b>	Cessation or upgrade of storm water overflows to comply with the criteria outlined in the DoECLG 'Procedures and Criteria in relation to Storm Water Overflows' (1995) - SW004	C	31/12/2020	No	Not Started		SWO Assessment Programme to assess performance against DoECLG criteri

A summary of the status of any improvements identified by under Condition 5.2 is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes		No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Relocate downstream ambient monitoring location
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 29/04/2020

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

## **7 APPENDIX**

There are no Appendices included