

Annual Environmental Report

2020



Cashel

D0171-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CASHEL WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CASHEL WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CASHEL WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CASHEL WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO CASHEL WWTP - 2020

3 COMPLAINTS SUMMARY

- 3.1 REPORTED INCIDENTS SUMMARY
 - 3.1.1 SUMMARY OF INCIDENTS
 - 3.1.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 AMBIENT MONITORING SUMMARY

Rev 1: Section 4.1.1 Question 1 answer changed to "Unknown". Approved 09/07/2021

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0171-01, Cashel, in Tipperary in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- CASHEL WWTP - 2020 with a Plant Capacity PE of 7000, the treatment type is 3P - Tertiary P removal

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2900D0171SW001	CASHEL WWTP - 2020	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CASHEL WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CASHEL WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	12	568	278.8
Total Phosphorus (as P) mg/l	12	6.7	3.61
Total Nitrogen mg/l	12	51.3	28.68
COD-Cr mg/l	12	1124	486.88
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	542	190.87
Hydraulic Capacity	N/A	5288	1797

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2900D0171SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	21.15	Pass
Suspended Solids mg/l	35	87.5	N/A	12	N/A	N/A	6.28	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	N/A	12	N/A	N/A	1.69	Pass
pH pH units	9	9	N/A	12	N/A	N/A	7.46	Pass
Ammonia-Total (as N) mg/l	5	6	N/A	12	N/A	N/A	0.58	Pass
ortho-Phosphate (as P) - unspecified mg/l	1.5	1.8	N/A	12	N/A	N/A	0.12	Pass
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.25	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	18.41	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2900D0171SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	204077, 141137	RS16S021430	No	No	No	No	Good
Downstream	203992, 140823	RS16S021440	No	No	No	No	Good

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD and Ortho P, concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CASHEL WWTP - 2020

2.1.4.1 Treatment Efficiency Report - CASHEL WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	118417	1046	99
TN	17794	11419	36
TP	2237	155	93
COD	302059	13120	96
SS	172968	3899	98

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - CASHEL WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

CASHEL WWTP - 2020	
Peak Hydraulic Capacity (m³/day) - As Constructed	6072
DWF to the Treatment Plant (m³/day)	2024

CASHEL WWTP - 2020	
Current Hydraulic Loading - annual max (m ³ /day)	5288
Average Hydraulic loading to the Treatment Plant (m ³ /day)	1797
Organic Capacity (PE) - As Constructed	7000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	5059
Organic Capacity (PE) - Remaining	1941
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CASHEL WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by tanker)	7525	Volume (m3)	100	100	Yes	Yes	Yes

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
There were no reportable incidents in 2020.				

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	0
Number of Incidents reported to the EPA via EDEN in 2020	0
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SWO02	206639, 140596	Yes	Medium	Not Meeting	Unknown	0	Monitored
TBC	TBC, TBC	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
TBC	207634, 140528	No	Medium	Meeting	Unknown	Unknown	Not Monitored
TBC	207518, 140481	No	Medium	Meeting	Unknown	Unknown	Unknown

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
There are no Specified Improvement Programmes for this Agglomeration.							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Drinking Water Abstraction Point Risk Assessment	Yes	2015	No	
Priority Substances Assessment	Yes		No	

5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT

The Drinking Water Abstraction Point Risk Assessment Report has been included in the AER 2015

5.2 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 09/07/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Cashel Ambient Monitoring Data 2020

								Parameter	Ammonia N	Biological Oxyg	COD Chemical	Dissolved Oxyg	Ortho-Phosph	pH	Temperature
								Max.	--	--	--	--	--	--	--
								Min.	--	--	--	--	--	--	--
								Test Method	--	--	--	--	--	--	--
Category	Entity	Station	Station Reference	Easting	Northing	Sample Refere	Sample Date	Analyst Conclu	mg/l	mg/l	mg/l	mg/l	mg/l	pH units	Degrees C
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20550083	21/01/2020	-	0.03	2		12.3	0.038	8.6	5.6
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20550082	21/01/2020	-	0.04	2		12.9	0.038	8.6	5.1
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20550249	12/02/2020	-	0.03	2.2		11.25	0.08	8.4	4.2
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20550246	12/02/2020	-	0.03	2.1		11.46	0.09	8.4	4.3
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20550039	04/03/2020	-	0.03	2		13.36	0.047	8.5	7.9
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20550038	04/03/2020	-	0.03	2		12.23	0.056	8.5	8.1
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20550563	06/05/2020	-	0.03	2		12.45	0.31	8.54	13.7
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20550564	06/05/2020	-	0.03	2		12.52	0.016	8.53	13.8
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20550758	17/06/2020	-	0.06	2		8.28	0.63	7.88	15.6
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20550757	17/06/2020	-	0.05	2		8.17	0.02	8.03	15
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20550906	08/07/2020	-	0.03	2.6		9.35	0.095	8.3	15.6
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20550905	08/07/2020	-	0.07	2		9.14	0.11	8.2	14.9
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20551122	26/08/2020	-	0.06	2		6.63	0.107	7.9	14.9
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20551121	26/08/2020	-	0.03	2		7.27	0.795	7.8	14.5
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20551204	16/09/2020	-	0.03	2		9.26	0.056	8.3	16.3
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20551205	16/09/2020	-	0.03	2		9.57	0.044	8.5	16.5
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20551325	08/10/2020	-	0.03	2		9.73	0.073	8.2	11.5
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20551326	08/10/2020	-	0.05	2		9.65	0.077	8.2	11.8
Ambient Monitoring	River Suir	Upstream @ Cashel WWTP	RS16S021510	204077	141137	20551538	11/11/2020	-	0.03	2.1		9.44	0.06	8.6	11.5
Ambient Monitoring	River Suir	Downstream @ Cashel WWTP	RS16S021410	203992	140823	20551537	11/11/2020	-	0.03	2		9.34	0.047	8.6	12