

Annual Environmental Report

2020



Creeslough

D0534-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 CREESLOUGH WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - CREESLOUGH WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - CREESLOUGH WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR CREESLOUGH WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO CREESLOUGH WWTP - 2020

3 COMPLAINTS SUMMARY

- 3.1 REPORTED INCIDENTS SUMMARY
 - 3.1.1 SUMMARY OF INCIDENTS
 - 3.1.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0534-01, Creeslough, in Donegal in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

Plan more frequent desludging of Imhoff tank at smaller volumes from Jan 2021

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Creeslough WWTP - 2020 with a Plant Capacity PE of 300, the treatment type is 2 - Secondary treatment

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF0600D0534SW001	Creeslough WWTP - 2020	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 CREESLOUGH WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - CREESLOUGH WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	6	136	78.75
COD-Cr mg/l	6	618	203.24
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	6	273	92.46
Hydraulic Capacity	N/A	263	171

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF0600D0534SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	6	1	N/A	41.51	Pass
Suspended Solids mg/l	35	87.5	N/A	6	1	N/A	15.81	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	25	50	N/A	6	N/A	N/A	9.04	Pass
pH pH units	9	9	N/A	6	N/A	N/A	7.09	Pass
Ammonia-Total (as N) mg/l	2	2.4	N/A	6	6	5	5.21	Fail
ortho-Phosphate (as P) - unspecified mg/l	1	1.2	N/A	6	5	4	1.72	Fail
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	2	N/A	N/A	5815.83	
Conductivity @20°C µS/cm	N/A	N/A	N/A	6	N/A	N/A	443.18	
E. Coli MPN/100ml	N/A	N/A	N/A	2	N/A	N/A	1982810.42	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Faecal coliforms cfu/100ml	N/A	N/A	N/A	2	N/A	N/A	1156355.6	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

No removal of Ortho P and Ammonia

Significance of Results:

The WWTP is non compliant with the ELVs set down in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF0600D0534SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	205359, 431675	RS38F010190	No	No	No	No	Good
Downstream	205467, 431677	RS38F010300	No	No	No	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS38F010190	1.67	RS38F010300	1.17	1.5	-33.3
Ammonia-Total (as N) mg/l	RS38F010190	0.02	RS38F010300	0.07	0.07	86.1
ortho-Phosphate (as P) - unspecified mg/l	RS38F010190	0.04	RS38F010300	0.04	0.04	7
Conductivity @20°C µS/cm	RS38F010190	165.5	RS38F010300	170.33		
Faecal coliforms cfu/100ml	RS38F010190	7099.5	RS38F010300	754		
Temperature °C	RS38F010190	10.97	RS38F010300	10.88		
Suspended Solids mg/l	RS38F010190	6.37	RS38F010300	6.2		
Dissolved Oxygen % Saturation	RS38F010190	98.6	RS38F010300	97.82		
pH pH units	RS38F010190	7.37	RS38F010300	7.43		

Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results does not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - CREESLOUGH WWTP - 2020

2.1.4.1 Treatment Efficiency Report - Creeslough WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	N/A	N/A	N/A
SS	4905	985	80
TN	N/A	N/A	N/A
COD	12660	2586	80
cBOD	5760	563	90

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Creeslough WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Creeslough WWTP - 2020	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	204

Creeslough WWTP - 2020	
DWF to the Treatment Plant (m ³ /day)	68
Current Hydraulic Loading - annual max (m ³ /day)	263
Average Hydraulic loading to the Treatment Plant (m ³ /day)	171
Organic Capacity (PE) - As Constructed	300
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	557
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - CREESLOUGH WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2020.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW002	205389, 431635	Yes	Low	Not Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NAY)	Status of Works	Timeframe for Completing the Work	Comments
D0534-SIP:01	Improvement works including nutrient reduction to ensure compliance with the ELVs as set out in Schedule A: Discharges and Discharge Monitoring of this licence.	C	31/12/2019	Yes	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.
D0534-SIP:02	Improvement works to ensure compliance with Condition 1.7	C	31/12/2019	Yes	Not Started		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 21/07/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

Municipality	Entity Name	Month	Location	Lab Ref	Date	pH	Temperature	Conductivity @ 20°C	DO	BOD	COD	Suspended Solids	Ammonia (as N)	Nitrate (as N)	Nitrite (as N)	Orthophosphate	Total Nitrogen	TON	Dissolved Inorganic Nitrogen DIN	Total Phosphorus	E coli	Enterococci	Faecal Coliforms	Chlorophyll	Salinity	SSRS	
Dungloe	Faymore	January	Creslough - Upstream	202500262	29-Jan-2020	7.3	6.2	127	96.2	3	NT	17	0.018	NT	NT	< 0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	January	Creslough - Downstream	202500265	29-Jan-2020	7.2	6.2	132	96	1	NT	16	0.026	NT	NT	< 0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	March	Creslough - Upstream	202501022	25-Mar-20	7.6	9.3	218	101.2	1	NT	<6	<0.015	NT	NT	<0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	March	Creslough - Downstream	202501025	25-Mar-20	7.6	8.9	204	101.4	1	NT	<6	<0.015	NT	NT	<0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	May	Creslough - Upstream	202501246	21-May-20	7.3	13.2	194	91.8	3	NT	<6	<0.015	NT	NT	<0.05	NT	NT	NT	NT	120	<10	63	NT	NT	NT	NT
Dungloe	Faymore	May	Creslough - Downstream	202501249	21-May-20	7.4	13.3	201	90.7	1	NT	<6	0.163	NT	NT	<0.05	NT	NT	NT	NT	1153	<10	884	NT	NT	NT	NT
Dungloe	Faymore	July	Creslough - Upstream	202502185	30-Jul-20	7.2	13.7	152	99.5	1	NT	<6	0.034	NT	NT	<0.05	NT	NT	NT	NT	14136	80	14136	NT	NT	NT	NT
Dungloe	Faymore	July	Creslough - Downstream	202502188	30-Jul-20	7.2	13.7	153	99.6	1	NT	<6	0.035	NT	NT	<0.05	NT	NT	NT	NT	836	90	624	NT	NT	NT	NT
Dungloe	Faymore	September	Creslough - Upstream	202502762	17-Sep-20	7.3	15.2	170	103.8	1	NT	<6	0.019	NT	NT	<0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	September	Creslough - Downstream	202502765	17-Sep-20	7.4	15	185	101	1	NT	<6	0.139	NT	NT	0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	November	Creslough - Upstream	202503367	04-Nov-20	7.5	8.2	132	99.1	1	NT	<6	<0.015	NT	NT	<0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT
Dungloe	Faymore	November	Creslough - Downstream	202503370	04-Nov-20	7.8	8.2	147	98.2	2	NT	<6	0.065	NT	NT	<0.05	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT	NT