

Annual Environmental Report

2020



Galway City

D0050-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 GALWAY WWTP - 2020 - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - GALWAY WWTP - 2020
 - 2.1.2 EFFLUENT MONITORING SUMMARY - GALWAY WWTP - 2020 -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR GALWAY WWTP - 2020
 - 2.1.5 SLUDGE/OTHER INPUTS TO GALWAY WWTP - 2020

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

7.1 OTHER

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0050-01, Galway City, in Galway in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- GALWAY WWTP - 2020 with a Plant Capacity PE of 170000, the treatment type is 2 - Secondary treatment

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1100D0050SW001	GALWAY WWTP - 2020	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 GALWAY WWTP - 2020 - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - GALWAY WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	26	782	346.45
Suspended Solids mg/l	26	336	196.1
Total Phosphorus (as P) mg/l	25	5.24	3.67
Total Nitrogen mg/l	26	27.3	16.16
BOD, 5 days with Inhibition (Carbonaceo mg/l	26	214	131.29
Hydraulic Capacity	N/A	83100	60971

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1100D0050SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	26	N/A	N/A	23.69	Pass
Total Nitrogen mg/l	35	42	N/A	26	N/A	N/A	12.57	Pass
Suspended Solids mg/l	35	87.5	N/A	26	N/A	N/A	6.14	Pass
Ammonia-Total (as N) mg/l	25	30	N/A	26	N/A	N/A	0.37	Pass
BOD, 5 days with Inhibition (Carbonaceo mg/l	25	50	N/A	26	N/A	N/A	3.18	Pass
Total Oxidised Nitrogen (as N) mg/l	20	24	N/A	26	N/A	N/A	10.17	Pass
pH pH units	9	9	N/A	26	N/A	N/A	7.71	Pass
Conductivity @20°C µS/cm	N/A	N/A	N/A	26	N/A	N/A	1741	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	24	N/A	N/A	0.46	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Enterococci (Intestinal) cfu/100ml	N/A	N/A	N/A	4	N/A	N/A	3086	
E. Coli MPN/100ml	N/A	N/A	N/A	4	N/A	N/A	8303	
Faecal coliforms MPN/100ml	N/A	N/A	N/A	4	N/A	N/A	10069	
Fats, Oils & Greases mg/l	N/A	N/A	N/A	4	N/A	N/A	8	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1100D0050SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
There is no ambient data included in the AER							

No ambient monitoring sampling was carried out for Galway City WWTP. However, the results for additional monitoring data sets (Bathing Water Results) are included in the Appendix 7.1 - Ambient monitoring summary

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

No ambient sampling was carried out.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - GALWAY WWTP - 2020

2.1.4.1 Treatment Efficiency Report - GALWAY WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
cBOD	2826810	70097	98
COD	7459149	522940	93
SS	4222199	135505	97
TN	347977	277444	20
TP	78277	10305	87

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - GALWAY WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

GALWAY WWTP - 2020	
Peak Hydraulic Capacity (m³/day) - As Constructed	135000
DWF to the Treatment Plant (m³/day)	45000
Current Hydraulic Loading - annual max (m³/day)	83100
Average Hydraulic loading to the Treatment Plant (m³/day)	60971
Organic Capacity (PE) - As Constructed	170000
Organic Capacity (PE) - Collected Load (peak week)^{Note1}	102558
Organic Capacity (PE) - Remaining	67442

GALWAY WWTP - 2020

Will the capacity be exceeded in the next three years? (Yes/No)

No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - GALWAY WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Landfill Leachate (delivered by sewer network)	73592	Volume (m3)		100	Yes	No	No

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
7	Blocked Sewer	1	6

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Spillage	Network Infrastructure	1	No	No
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Uncontrolled release	Broken Sewer Pipe	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Spillage	Broken Sewer Pipe	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	4
Number of Incidents reported to the EPA via EDEN in 2020	4
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
SW005	133295, 224745	Yes	Low	Not yet Assessed	Unknown	Unknown	Monitored
SW006	137761, 224817	Yes	Low	Not yet Assessed	Unknown	Unknown	Monitored
SW007	131556, 227566	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Monitored
SW008	129696, 224768	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SW017	126016, 223779	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SW018	128635, 224062	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status N/A
SW019	129812, 224776	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SW020	129645, 225526	Yes	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored
SW021	131301, 225796	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SW022	131199, 226070	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SW023	132375, 224416	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored
SWOO2	129581, 223202	Yes	Low	Not yet Assessed	Unknown	0	Monitored
SWOO3	126009, 223156	Yes	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0050-SIP:01	SW009 (SD09) to be discontinued	A	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:02	SW011 (SD11) to be discontinued	A	21/12/2015	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0050-SIP:03	SW012 (SD12) to be discontinued	A	01/05/2011	Yes	Works Completed		
D0050-SIP:04	SW013 (SD13) to be discontinued	A	21/12/2015	Yes	Works Completed		
D0050-SIP:05	SW014 (SD14) to be discontinued	A	01/05/2011	Yes	Works Completed		
D0050-SIP:06	SW015 (SD15) to be discontinued	A	01/05/2011	Yes	Works Completed		
D0050-SIP:07	WWTP upgrade and ancillary works	C	01/09/2012	Yes	Works Completed		
D0050-SIP:08	Upgrade to SWO -SD10	C	01/05/2014	Yes	Works Completed		
D0050-SIP:09	Upgrading of SWO02 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/09/2012	Yes	Works Completed		
D0050-SIP:10	Upgrading of SWO03 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0050-SIP:11	Upgrading of SWO05 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:12	Upgrading of SWO06 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:13	Upgrading of SWO07 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:14	Upgrading of SWO08 Storm Water Overflows to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:15	Upgrading of SWO17 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0050-SIP:16	Upgrading of SWO18 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:17	Upgrading of SWO19 Storm Water Overflow to comply with the criteria outlined in DoEHLG.	C	01/05/2014	No	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:18	Upgrading of SWO20 Storm Water Overflow to comply with the criteria outlined in DoEHLG.	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:19	Upgrading of SWO21 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+
D0050-SIP:20	Upgrading of SWO22 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	At Planning Stage		Drainage Area Plan Investigation Study to be completed. Completion date 2024+

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0050-SIP:21	Upgrading of SWO23 Storm Water Overflow to comply with the criteria outlined in DoEHLG	C	01/05/2014	Yes	Works Completed		
D0050-SIP:22	Replacement of stand-by pump at Parkavera Pumping Station SD04 emergency overflow	C	14/07/2010	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
There are no Improvements Programme for this Agglomeration.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2014	No	

5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2014

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	N/A
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	N/A
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	Yes

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed: Date: 21/05/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Other

Ballyloughane Beach

Date	E-Coli Result	Intestinal Enterocci Result	Water Sample Status
14/09/2020	86	7	Excellent
07/09/2020	109	131	Good
31/08/2020	109	21	Excellent
24/08/2020	41	5	Excellent
17/08/2020	189	37	Excellent
10/08/2020	62	7	Excellent
04/08/2020	256	55	Good
27/07/2020	20	2	Excellent
20/07/2020	63	19	Excellent
13/07/2020	98	22	Excellent
06/07/2020	31	20	Excellent
29/06/2020	52	5	Excellent
22/06/2020	10	6	Excellent
15/06/2020	10	2	Excellent
08/06/2020	<10	2	Excellent
02/06/2020	<10	2	Excellent
25/05/2020	<10	2	Excellent
10/09/2019	160	23	Excellent
09/09/2019	31	9	Excellent
26/08/2019	216	15	Excellent
19/08/2019	119	30	Excellent
12/08/2019	52	6	Excellent
29/07/2019	31	5	Excellent
22/07/2019	3130	520	Poor
15/07/2019	63	17	Excellent
08/07/2019	109	23	Excellent
01/07/2019	10	2	Excellent
24/06/2019	<10	6	Excellent
17/06/2019	243	130	Good
10/06/2019	<10	4	Excellent
04/06/2019	10	23	Excellent
30/05/2019	175	37	Excellent
10/09/2018	110	180	Good
03/09/2018	20	3	Excellent
27/08/2018	275	110	Good
20/08/2018	10	3	Excellent
13/08/2018	135	60	Excellent
07/08/2018	292	25	Good
30/07/2018	1421	270	Poor
23/07/2018	31	6	Excellent
16/07/2018	75	36	Excellent
09/07/2018	10	2	Excellent
02/07/2018	10	2	Excellent

25/06/2018	10	2	Excellent
18/06/2018	20	9	Excellent
11/06/2018	10	3	Excellent
05/06/2018	10	2	Excellent
28/05/2018	10	8	Excellent
11/09/2017	197	75	Excellent

Grattan Beach

Date	E-Coli Result	Intestinal Enterocci Result	Water Sample Status
14/09/2020	20	8	Excellent
07/09/2020	697	60	Sufficient
31/08/2020	98	50	Excellent
24/08/2020	20	6	Excellent
17/08/2020	161	15	Excellent
10/08/2020	20	2	Excellent
04/08/2020	63	16	Excellent
27/07/2020	10	2	Excellent
20/07/2020	20	17	Excellent
13/07/2020	246	14	Excellent
06/07/2020	74	8	Excellent
29/06/2020	598	98	Sufficient
22/06/2020	63	39	Excellent
15/06/2020	<10	3	Excellent
08/06/2020	73	10	Excellent
02/06/2020	218	8	Excellent
25/05/2020	10	2	Excellent
09/09/2019	175	15	Excellent
02/09/2019	203	34	Excellent
26/08/2019	288	150	Good
19/08/2019	63	8	Excellent
12/08/2019	31	11	Excellent
29/07/2019	63	9	Excellent
22/07/2019	677	170	Sufficient
15/07/2019	52	11	Excellent
08/07/2019	85	31	Excellent
01/07/2019	<10	2	Excellent
24/06/2019	10	9	Excellent
17/06/2019	464	173	Good
10/06/2019	30	10	Excellent
04/06/2019	52	57	Excellent
30/05/2019	441	25	Good
10/09/2018	1607	360	Poor
03/09/2018	110	10	Excellent
27/08/2018	86	25	Excellent
20/08/2018	63	2	Excellent
13/08/2018	52	37	Excellent
07/08/2018	428	320	Poor
30/07/2018	644	160	Sufficient
23/07/2018	98	3	Excellent
16/07/2018	384	121	Good
09/07/2018	10	2	Excellent
02/07/2018	10	5	Excellent

25/06/2018	110	23	Excellent
18/06/2018	253	13	Good
11/06/2018	10	2	Excellent
05/06/2018	10	2	Excellent
28/05/2018	145	180	Good
11/09/2017	216	43	Excellent

Salthill Beach

Date	E-Coli Result	Intestinal Enterocci Result	Water Sample Status
07/09/2020	74	2	Excellent
24/08/2020	41	3	Excellent
10/08/2020	<10	2	Excellent
27/07/2020	<10	2	Excellent
13/07/2020	30	3	Excellent
29/06/2020	20	6	Excellent
15/06/2020	<10	7	Excellent
02/06/2020	20	5	Excellent
25/05/2020	<10	2	Excellent
09/09/2019	10	2	Excellent
26/08/2019	10	8	Excellent
12/08/2019	10	13	Excellent
29/07/2019	20	2	Excellent
15/07/2019	<10	2	Excellent
01/07/2019	<10	6	Excellent
17/06/2019	10	18	Excellent
04/06/2019	20	2	Excellent
30/05/2019	10	6	Excellent
10/09/2018	10	3	Excellent
27/08/2018	63	3	Excellent
13/08/2018	10	7	Excellent
30/07/2018	10	2	Excellent
16/07/2018	31	9	Excellent
02/07/2018	10	2	Excellent
18/06/2018	10	2	Excellent
05/06/2018	10	2	Excellent
28/05/2018	10	2	Excellent
11/09/2017	299	15	Good
28/08/2017	10	10	Excellent
14/08/2017	121	13	Excellent
31/07/2017	10	2	Excellent
17/07/2017	10	2	Excellent
03/07/2017	10	2	Excellent
19/06/2017	20	2	Excellent
06/06/2017	10	2	Excellent
29/05/2017	31	2	Excellent
12/09/2016	41	2	Excellent
29/08/2016	20	7	Excellent
15/08/2016	74	2	Excellent
02/08/2016	41	41	Excellent
18/07/2016	10	2	Excellent
04/07/2016	41	20	Excellent
20/06/2016	20	4	Excellent

07/06/2016	10	3	Excellent
23/05/2016	20	8	Excellent
14/09/2015	98	35	Excellent
31/08/2015	41	16	Excellent
17/08/2015	243	23	Excellent
04/08/2015	75	24	Excellent

Silverstrand Beach

Date	E-Coli Result	Intestinal Enterocci Result	Water Sample Status
07/09/2020	52	14	Excellent
24/08/2020	20	2	Excellent
10/08/2020	20	2	Excellent
27/07/2020	10	2	Excellent
13/07/2020	<10	2	Excellent
29/06/2020	<10	62	Excellent
15/06/2020	<10	2	Excellent
02/06/2020	<10	2	Excellent
25/05/2020	<10	2	Excellent
09/09/2019	<10	2	Excellent
26/08/2019	<10	2	Excellent
12/08/2019	<10	2	Excellent
29/07/2019	<10	2	Excellent
15/07/2019	20	2	Excellent
01/07/2019	<10	2	Excellent
17/06/2019	108	62	Excellent
04/06/2019	<10	3	Excellent
30/05/2019	31	6	Excellent
10/09/2018	31	39	Excellent
27/08/2018	233	64	Excellent
13/08/2018	10	72	Excellent
30/07/2018	31	5	Excellent
16/07/2018	31	20	Excellent
02/07/2018	10	2	Excellent
18/06/2018	10	2	Excellent
05/06/2018	10	15	Excellent
28/05/2018	10	3	Excellent
11/09/2017	20	6	Excellent
28/08/2017	10	4	Excellent
14/08/2017	52	13	Excellent
31/07/2017	10	3	Excellent
17/07/2017	10	2	Excellent
03/07/2017	10	2	Excellent
19/06/2017	10	2	Excellent
06/06/2017	10	2	Excellent
29/05/2017	10	2	Excellent
12/09/2016	10	2	Excellent
29/08/2016	10	3	Excellent
15/08/2016	10	2	Excellent
02/08/2016	96	90	Excellent
18/07/2016	10	2	Excellent

04/07/2016	288	110	Good
20/06/2016	20	2	Excellent
07/06/2016	10	2	Excellent
23/05/2016	10	4	Excellent
14/09/2015	41	30	Excellent
31/08/2015	52	11	Excellent
17/08/2015	41	3	Excellent
04/08/2015	134	38	Excellent