

# Annual Environmental Report

2020



Rochfortbridge

D0101-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ROCHFORTBRIDGE WWTP - 2020 - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ROCHFORTBRIDGE WWTP - 2020
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ROCHFORTBRIDGE WWTP - 2020 -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ROCHFORTBRIDGE WWTP - 2020
  - 2.1.5 SLUDGE/OTHER INPUTS TO ROCHFORTBRIDGE WWTP - 2020

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0101-01, Rochfortbridge, in Westmeath in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no major capital or operational changes undertaken in 2020.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Rochfortbridge WWTP - 2020 with a Plant Capacity PE of 4500, the treatment type is 3NP - Tertiary N&P removal

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
<b>TPEFF3200D0101SW001</b>	Rochfortbridge WWTP - 2020	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceous) mg/l Total Phosphorus mg/l

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
<b>There are no Licence Specific Reports included in the AER.</b>	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ROCHFORTBRIDGE WWTP - 2020 - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ROCHFORTBRIDGE WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD - 5 days (Total) mg/l	12	1425.00	392.05
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	560.00	230.38
COD-Cr mg/l	12	5810.00	1165.14
Suspended Solids mg/l	12	3150.00	627.57
Total Nitrogen mg/l	12	99.10	57.76
Total Phosphorus (as P) mg/l	12	32.30	11.65
Hydraulic Capacity	N/A	699.84	459.95

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3200D0101SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Chemical Oxygen Demand mg/l	125	250	N/A	12	N/A	N/A	24.63	Pass
Suspended Solids mg/l	35	87.5	N/A	12	N/A	N/A	5.33	Pass
pH pH units	6-9	6-9	N/A	12	N/A	N/A	7.35	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	4	8	N/A	12	3	1	2.47	Fail
Ammonia-Total (as N) mg/l	0.36	0.72	N/A	12	1	1	0.28	Fail
Total Phosphorus mg/l	0.27	0.32	N/A	12	2	2	0.13	Fail
Conductivity @20°C µS/cm	N/A	N/A	N/A	12	N/A	N/A	648.72	
Nitrate (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	15.97	
Nitrite (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.17	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	12	N/A	N/A	0.07	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	18.31	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	16.11	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

WWTP biological sludge issue & Inadequate infrastructure.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3200D0101SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	246905 240424	RS07R040980	No	No	No	No	Poor
Downstream	247094, 240454	RS07R040990	No	No	No	No	Poor *

\* WFD status is Good ca. 450 m d/s of this point.

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ammonia & Ortho-P concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.



## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ROCHFORTBRIDGE WWTP - 2020

### 2.1.4.1 Treatment Efficiency Report - Rochfortbridge WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>cBOD</b>	25408	400	98
<b>COD</b>	128504	3990	97
<b>SS</b>	69215	863	99
<b>TN</b>	6371	2966	53
<b>TP</b>	1285	21	98

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Rochfortbridge WWTP - 2020

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Rochfortbridge WWTP - 2020	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	3039
DWF to the Treatment Plant (m <sup>3</sup> /day)	1013
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	699.84
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	459.95
Organic Capacity (PE) - As Constructed	4500
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	2122
Organic Capacity (PE) - Remaining	2378
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

### 2.1.5 SLUDGE / OTHER INPUTS - ROCHFORTBRIDGE WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2020.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Breach of ELV</b>	Inadequate Infrastructure	1	Yes	No
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Breach of ELV</b>	WWTP biological sludge issue	1	No	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	3
Number of Incidents reported to the EPA via EDEN in 2020	3
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m <sup>3</sup> )	Monitoring Status
SW006	247004, 240439	Yes	Low	Meeting	Unknown	Unknown	Not Monitored
SW4	246540, 240990	Yes	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m <sup>3</sup> )?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0101-SIP:01</b>	Discharge to cease: SW1 to Rochfortbridge stream	A	09/02/2010	Yes	Works Completed		
<b>D0101-SIP:02</b>	Discharge to cease: SW2 to Rochfortbridge stream	A	09/02/2010	Yes	Works Completed		
<b>D0101-SIP:03</b>	New WWTP plant (phase 1) and ancillary works	C	09/02/2010	Yes	Works Completed		
<b>D0101-SIP:04</b>	Installation and connection of Mullingar Road pumping station	C	09/02/2010	Yes	Works Completed		

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0101-SIP:05</b>	Installation of new inlet pumping station	C	09/02/2010	Yes	Works Completed		
<b>D0101-SIP:06</b>	Installation of storm water storage tank	C	09/02/2010	Yes	Works Completed		
<b>D0101-SIP:07</b>	Phase 2 upgrade of new WWTP	C	31/12/2020	No	Not Started		Capital works not funded in RC3. Capital works funding post 2024 will be contingent on the project being included in the 2025-2029 investment period.
<b>D0101-SIP:08</b>	Refurbishment of old WWTP	C	09/02/2011	Yes	Works Completed		
<b>D0101-SIP:09</b>	Upgrading of SW2a SWO to ensure compliance with DoEHLG criteria.	C	02/02/2010	Yes	Works Completed		

A summary of the status of any improvements identified by under Condition 5.2 is included below.

#### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### **4.2.3 SEWER INTEGRITY RISK ASSESSMENT**

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2012	No	N/A

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2012.

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 30/03/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

## Rochfortbridge 2020 Ambient Monitoring Summary

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	246905 240424	RS07R040980	No	No	No	No
Downstream Monitoring Point	247094, 240454	RS07R040990	No	No	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD (Mean mg/l)	o-Phosphate (as P) (Mean mg/l)	Ammonia (as N) (mean mg/l)
Upstream Monitoring Point	Poor	1.321	0.021	0.048
Downstream Monitoring Point	Poor	1.323	0.027	0.093
<i>Difference</i>		0.002	0.007	0.045
EQS		1.500	0.035	0.065
% of EQS		0.109%	18.603%	68.639%

## Rochfortbridge 2020 Ambient Monitoring Data

Details/Coordinates	Sample Date	Temperature °C	pH units	pH	BOD mg/l	Total Nitrogen mg/l	Ammonia mg/l as N	Ortho-Phosphate mg/l as P	DO mg/l	DO % sat
Upstream	14/01/2020	6.9	7.5	1.3	3.3	0.076	0.021	10.47	89.7	
Upstream	11/02/2020	7.2	7.6	1.8	4.6	0.056	0.009	10.83	91.6	
Upstream	10/03/2020	10.9	7.6	1.1	3.7	0.054	0.029	9.61	91	
Upstream	05/05/2020	13.4	7.9	< 2	4.9	0.013	< 0.025	9.6	92	
Upstream	09/06/2020	14.6	8	2	5.6	0.014	0.025	8.75	86	
Upstream	30/06/2020	16.2	8	< 2	< 2.5	0.021	< 0.025	7.61	78.9	
Upstream	08/07/2020	13.8	7.8	< 2	< 2.5	0.101	< 0.025	7.67	74.5	
Upstream	04/08/2020	16.3	7.7	< 2	< 2.5	0.118	< 0.025	6.84	70.9	
Upstream	02/09/2020	15.9	7.8	< 2	< 2.5	0.048	< 0.025	6.85	71	
Upstream	06/10/2020	12.6	8.4	1.1	< 2.5	0.037	0.022	7.97	76.9	
Upstream	14/10/2020	10.8	7.9	1.1	< 2.5	0.036	0.034	8.9	79.9	
Upstream	01/12/2020	8.5	7.9	< 1	2.8	0.037	0.018	9.17	78.3	
Upstream	08/12/2020	6.5	8	1	2.9	0.013	0.021	9.97	82.3	
	<b>Mean</b>			<b>1.321</b>		<b>0.048</b>	<b>0.021</b>	<b>8.79</b>	<b>81.8</b>	
	<b>95%ile</b>			<b>1.88</b>		<b>0.108</b>	<b>0.031</b>	<b>10.61</b>	<b>91.8</b>	
Downstream	14/01/2020	7.9	7.7	2.3	3.2	0.074	0.017	10.27	90.2	
Downstream	11/02/2020	7.4	7.6	1.6	4.8	0.023	0.015	10.73	91.8	
Downstream	10/03/2020	11.5	7.6	< 1	3.7	0.084	0.024	9.62	90.2	
Downstream	05/05/2020	13.2	7.9	< 2	5.4	0.236	< 0.025	9.84	94	
Downstream	09/06/2020	14.9	7.8	< 2	9.9	0.02	0.037	8.79	87.5	
Downstream	30/06/2020	16.3	8	< 2	4.3	0.027	< 0.025	8.07	83.8	
Downstream	08/07/2020	13.3	7.8	< 2	< 2.5	0.081	< 0.025	7.74	74.2	
Downstream	04/08/2020	16.2	7.7	< 2	6.9	0.319	0.027	6.75	69	
Downstream	02/09/2020	15.9	7.8	< 2	< 2.5	0.051	0.078	6.79	69.9	
Downstream	06/10/2020	11.4	8.4	< 1	< 2.5	0.039	0.033	7.92	74.3	
Downstream	14/10/2020	10.7	7.9	1.7	< 2.5	0.182	0.028	8.54	76.5	
Downstream	01/12/2020	8.8	7.8	1.2	2.9	0.055	0.017	9.25	79.1	
Downstream	08/12/2020	6.2	8	< 1	3.2	0.013	0.023	10.18	83.5	
	<b>Mean</b>			<b>1.323</b>		<b>0.093</b>	<b>0.027</b>	<b>8.81</b>	<b>81.8</b>	
	<b>95%ile</b>			<b>1.94</b>		<b>0.269</b>	<b>0.053</b>	<b>10.45</b>	<b>92.7</b>	

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.