

Annual Environmental Report

2022



Lower Liffey Valley Regional Sewerage Scheme -

D0004-02

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 LOWER LIFFEY VALLEY WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - LOWER LIFFEY VALLEY WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - LOWER LIFFEY VALLEY WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR LOWER LIFFEY VALLEY WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO LOWER LIFFEY VALLEY WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 PRIORITY SUBSTANCES ASSESSMENT
- 5.2 TOXICITY/LEACHATE MANAGEMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 AMBIENT MONITORING SUMMARY

<u>Revision Number</u>	<u>Description of Change</u>	<u>Date of Approval</u>
1	Ambient data included	27/04/2023

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0004-02, Lower Liffey Valley Regional Sewerage Scheme, in Kildare in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

An automatic control of caustic dosing was completed in 2022.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Lower Liffey Valley WWTP with a Plant Capacity PE of 150000, the treatment type is 3NP - Tertiary N&P removal.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1400D0004SW001	Lower Liffey Valley WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 LOWER LIFFEY VALLEY WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - LOWER LIFFEY VALLEY WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Ammonia-Total (as N) mg/l	24	36	29
ortho-Phosphate (as P) - unspecified mg/l	24	5.95	2.67
Total Nitrogen mg/l	24	64	43
Suspended Solids mg/l	24	242	153
Total Phosphorus (as P) mg/l	24	8.20	3.47
COD-Cr mg/l	24	766	343
BOD, 5 days with Inhibition (Carbonaceous) mg/l	24	578	226
pH pH units	24	7.52	7.29
Hydraulic Capacity	N/A	52923	38400

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1400D0004SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	24	N/A	N/A	12	Pass
Suspended Solids mg/l	35	88	N/A	24	N/A	N/A	3.27	Pass
pH pH units	6.00	9.00	N/A	24	N/A	N/A	6.77	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	4.00	8.00	N/A	24	N/A	N/A	1.00	Pass
Total Phosphorus (as P) mg/l	1.00	1.20	N/A	24	N/A	N/A	0.081	Pass
Ammonia-Total (as N) mg/l	0.500	1.00	N/A	24	N/A	N/A	0.103	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.100	0.200	N/A	24	N/A	N/A	0.040	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	24	N/A	N/A	14	
Total Nitrogen mg/l	N/A	N/A	N/A	24	N/A	N/A	14	
Nitrite (as N) mg/l	N/A	N/A	N/A	24	N/A	N/A	0.020	
Appearance (on Sampling) Descriptive	N/A	N/A	N/A	24	N/A	N/A	N/A	
True Colour PtCo Units	N/A	N/A	N/A	23	N/A	N/A	12	
Fluoride mg/l	N/A	N/A	N/A	24	N/A	N/A	2.77	
Nitrate (as N) mg/l	N/A	N/A	N/A	24	N/A	N/A	14	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE

TPEFF1400D0004SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	301516, 235804	RS09L011940	No	No	No	No	Poor
Downstream	302295, 235190	RS09L012040	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ortho-phosphate & Ammonia concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it is or is not caused by the WWTP.

The Lower Liffey Valley agglomeration was listed as a pressure in the Cycle 2 Liffey and Dublin Bay Catchment Report (HA09) but has been removed from the list of significant pressures in Cycle 3.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - LOWER LIFFEY VALLEY WWTP

2.1.4.1 Treatment Efficiency Report - Lower Liffey Valley WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TP	47885	1122	98
COD	4728572	169914	96
TN	594042	199670	66
SS	2108778	45164	98
cBOD	3116871	13584	100

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - Lower Liffey Valley WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Lower Liffey Valley WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	65405
DWF to the Treatment Plant (m ³ /day)	48500
Current Hydraulic Loading - annual max (m ³ /day)	52923
Average Hydraulic loading to the Treatment Plant (m ³ /day)	38400
Organic Capacity (PE) - As Constructed	150000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	140458
Organic Capacity (PE) - Remaining	9542
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - LOWER LIFFEY VALLEY WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
Domestic /Septic Tank Sludge	18722	Weight (Tonnes)	228	0.13	Yes	Yes	Yes
Landfill Leachate (delivered by tanker)	13429	Weight (Tonnes)	163.5	0.1	Yes	Yes	Yes
Industrial / Commercial Sludge	9343	Weight (Tonnes)	113.8	0.07	Yes	Yes	Yes
Other	31	Weight (Tonnes)	0.04	0	Yes	Yes	Yes

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
1	Discharge to waters	1	0

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Uncontrolled release	EO caused by pump failure	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	Network Infrastructure	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	EO caused by pump failure	1	No	Yes
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes
Uncontrolled release	Broken Sewer Pipe	1	No	No
Uncontrolled release	SWO exceptional rainfall and overflow expected	1	No	Yes

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	13
Number of Incidents reported to the EPA via EDEN in 2022	13
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	Total volume discharged in 2022 (m ³)	Monitoring Status
SW002	TBC TBC	Yes	Low Significance	Meeting Criteria	6,413	Monitored
TBC	297590 233306	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
SW005	293552 237349	Yes	Low Significance	Not Meeting Criteria	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	Total volume discharged in 2022 (m ³)	Monitoring Status
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
SW013	301155 TBC	Yes	Low Significance	Not Meeting Criteria	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
SW016	30653 TBC	Yes	Low Significance	Not Meeting Criteria	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
SW010	298651 233371	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
SW003	288852 239591	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
SW011	298651 233385	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	Total volume discharged in 2022 (m ³)	Monitoring Status
SW004	294407 238711	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
TBC	286684 240780	Yes	Low Significance	Not yet Assessed	Unknown	TBC
TBC	287403 240465	Yes	TBC	Not yet Assessed	Unknown	TBC
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	TBC
SW008	297584 233306	Yes	Low Significance	Not Meeting Criteria	Unknown	Not Monitored
SW007	297590 233306	Yes	Low Significance	Not Meeting Criteria	Unknown	Not Monitored
SW009	297379 232919	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
SW015	300408 235903	Yes	Low Significance	Not Meeting Criteria	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	Total volume discharged in 2022 (m ³)	Monitoring Status
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
TBC	TBC TBC	Yes	Low Significance	Not yet Assessed	Unknown	Monitored
SW014	292832 229607	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
SW006	298236 233802	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
TBC	298236 233802	Yes	Low Significance	Not yet Assessed	Unknown	Not Monitored
SW012	296932 232421	Yes	Low Significance	Meeting Criteria	Unknown	Not Monitored
TBC	288434 238610	Yes	Low Significance	Not yet Assessed	Unknown	TBC
TBC	288177 239026	Yes	Low Significance	Not yet Assessed	Unknown	TBC
TBC	287770 240274	Yes	Low Significance	Not yet Assessed	Unknown	TBC
TBC	299292 234119	Yes	Low Significance	Not yet Assessed	Unknown	TBC
TBC	300469 235248	Yes	Low Significance	Not yet Assessed	Unknown	TBC

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	Total volume discharged in 2022 (m ³)	Monitoring Status
TBC	293095 238364	Yes	TBC	Not yet Assessed	Unknown	TBC
TBC	296916 232422	Yes	TBC	Not yet Assessed	Unknown	TBC

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m ³)?	6,413
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	Yes
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0004-SIP:01	Upgrading of Storm Water Overflows to comply with the criteria outlined in the DoECLG "Procedures and Criteria in relation to Storm Water Overflows, 1995".	C	31/12/2020	No	Work ongoing on-site	2025	DAP assessment on-going.
D0004-SIP:02	Waste Water capacity improvement works	C	08/05/2020	Yes	Works Completed		
D0004-SIP:03	Waste Water Treatment plant improvement and ancillary works to meet the requirements of Schedule A.1 and condition 3.4	C	31/12/2019	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2014	No
Toxicity/Leachate Management	Yes	2014	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 25/02/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix
Appendix 7.1 - Ambient Monitoring Summary

Lower Liffey Valley WWTP Ambient Monitoring Summary 2022

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				Current WFD Status	Mean (mg/l)		
			Bathing Water	Drinking Water	FWPM	Shellfish		cBOD	o-Phosphate (as P)	Ammonia (as N)
Upstream Monitoring Point	301516, 235804	RS09L011940	No	No	No	No	Poor	1.000	0.0396	0.1051
Downstream Monitoring Point	302295, 235190	RS09L012040	No	No	No	No	Poor	1.000	0.0400	0.1054
<i>Difference</i>								<i>0.0000</i>	<i>0.0004</i>	<i>0.0003</i>
EQS								1.500	0.035	0.065
% of EQS								0.000%	1.099%	0.473%

Lower Liffey Valley WWTP Ambient Monitoring Summary 2022

Upstream Results														
Date		Temp oC	pH pH units	BOD mg/l	COD mg/l	Suspended solids mg/l	Total Nitrogen mg/l	Total Phosphorus mg/l	Ammonia mg/l	Ortho- Phosphate mg/l	Nitrite mg/l	Nitrate mg/l	DO mg/l	DO % sat
12-Jan-2022	U/S	10.7	7.5	1	22	4	4.1	0.16	0.14	0.1	0.01	3.11	10.3	90.2
19-Jan-2022	U/S	8.2	8.2	1	1	2	3.1	0.13	0.08	0.03	0.01	3.02	10.9	91.2
26-Jan-2022	U/S	8.9	7.8	1	26	1	3	0.11	0.07	0.07	0.01	2.9	11.2	94.9
9-Feb-2022	U/S	7.4	7.41	1	15	10	4.2	0.19	0.25	0.13	0.03	2.86	10.6	94
24-Feb-2022	U/S	8.6	7.4	1	12	8	3.1	0.12	0.18	0.08	0.01	2.99	10.9	93.5
2-Mar-2022	U/S	8	7.25	1	15	5	2.4	0.09	0.18	0.05	0.01	2.27	11.1	94
22-Mar-2022	U/S	11.8	7.32	1	13	4	4.2	0.07	0.04	0.06	0.01	2.16	10.2	93.2
30-Mar-2022	U/S	12.7	7.55	1	11	4	2.2	0.08	0.05	0.01	0.01	2.63	9.8	92.4
20-Apr-2022	U/S	15	7.66	1	8	1	4.6	0.08	0.13	0.02	0.01	2.24	9.9	97.4
27-Apr-2022	U/S	14.8	7.36	1	27	2	2.6	0.09	0.012	0.05	0.03	2.49	10.2	99.2
11-May-2022	U/S	17.9	7.62	1	21	1	2.2	0.05	0.07	0.02	0.01	1.76	10.3	106
18-May-2022	U/S	17.9	7.31	1	12	1	1.1	0.02	0.08	0.05	0.01	1.63	9.1	96
22-June-2022	U/S	18.8	7.5	1	14	2	1.8	0.05	0.08	0.02	0.01	1.7	8.5	91.6
30-June-2022	U/S	18	7.44	1	11	1	1.6	0.03	0.07	0.01	0.01	1.53	9.1	95.7
6-July-2022	U/S	19.7	7.52	1	101	2	3.6	0.07	0.03	0.01	0.02	1.57	8.7	94.1
13-July-2022	U/S	19.7	7.31	1	18	1	1.4	0.06	0.08	0.03	0.01	1.35	9.2	99.2
10-Aug-2022	U/S	19	7.32		9	3	1.5		0.08	0.05	0.01	1.42	9.4	99.6
25-Aug-2022	U/S	20.2	6.95		8	1	2.4	0.1	0.08	0.02	0.01	1.37	8.4	92.4
7-Sep-2022	U/S	17	6.96	1	11	2	1.8	0.04	0.04	0.02	0.01	1.71	8.8	88.3
28-Sep-2022	U/S	15	7.44	1	4	3	1.8	0.05	0.05	0.02	0.01	1.83	9.3	92.8
19-Oct-2022	U/S	14.9	7.35	1	10	2	1.8	0.06	0.07	0.04	0.01	1.73	9.2	92.7
26-Oct-2022	U/S	14.1	7.38	1	24	2	2.5	0.05	0.22	0.03	0.01	2.5	9.7	96
17-Nov-2022	U/S	12.6	7.51	1	5	3	2.3	0.04	0.06	0.02	0.01	2.22	9.5	91.3
30-Nov-2022	U/S	11	7.3	1	11	4	2.03	0.06	0.19	0.03	0.02	1.87	10.2	91.6
7-Dec-2022	U/S	10.5	7.31	1	13	1	2.05	0.05	0.21	0.03	0.02	1.94	10.2	89.8
14-Dec-2022	U/S	7.2	7.14	1	7	4	1.92	0.06	0.19	0.03	0.03	1.86	10.8	89.6
Mean		13.831	7.416	1.000	16.500	2.846	2.512	0.076	0.1051	0.0396	0.013	2.102	9.827	94.104
95%ile		19.700	7.765	1.000	26.750	7.250	4.200	0.154	0.218	0.095	0.030	3.013	11.050	99.500

Downstream Results														
Date		Temp oC	pH pH units	BOD mg/l	COD mg/l	Suspended solids mg/l	Total Nitrogen mg/l	Total Phosphorus mg/l	Ammonia mg/l	Ortho- Phosphate mg/l	Nitrite mg/l	Nitrate mg/l	DO mg/l	DO % sat
12-Jan-2022	D/S	8.9	7.6	1	13	2	4.4	0.14	0.16	0.09	0.03	3.3	11.03	92.7
19-Jan-2022	D/S	6.8	8.2	1	12	2	3.5	0.08	0.07	0.06	0.02	3.4	11.7	94.5
26-Jan-2022	D/S	8.5	7.8	1	9	2	4.3	0.11	0.09	0.07	0.02	4.2	11.2	94.1
9-Feb-2022	D/S	10	55	1	17	10	4	0.19	0.25	0.13	0.03	3.05	10.7	94.1
24-Feb-2022	D/S	8.3	7.4	1	9	7	3.2	0.04	0.21	0.02	0.02	3.02	11.03	94.1
2-Mar-2022	D/S	11.2	7.37	1	14	4	4.6	0.1	0.06	0.06	0.01	2.6	11.2	94
22-Mar-2022	D/S	11.6	7.55	1	14	4	4.6	0.1	0.06	0.06	0.01	2.6	10.2	92.9
30-Mar-2022	D/S	12.2	7.7	1	13	3	4	0.08	0.07	0.02	0.01	3.08	9.8	91.6
20-Apr-2022	D/S	12.3	7.79	1	24	1	6.5	0.06	0.14	0.01	0.01	3.15	10.6	98.4
27-Apr-2022	D/S	12.9	7.7	1	26	3	2.9	0.08	0.01	0.04	0.02	2.58	12.2	113
11-May-2022	D/S	16.9	7.59	1	19	2	3.2	0.05	0.1	0.02	0.01	2.76	9.2	96
18-May-2022	D/S	16.5	7.53	1	8	2	2.1	0.02	0.12	0.06	0.01	2.51	9.42	96.4
22-June-2022	D/S	18.2	7.53	1	19	2	2.7	0.05	0.08	0.02	0.01	2.68	8.4	88.8
30-June-2022	D/S		7.44		11	1	2.4	0.03	0.07	0.01	0.01	2.42		
6-July-2022	D/S	19.4	7.61	1	13	2	4.6	0.08	0.05	0.01	0.01	2.22	9.3	97.4
13-July-2022	D/S	20.7	7.29	1	24	1	2.2	0.08	0.06	0.05	0.01	2.1	8.9	97.8
10-Aug-2022	D/S	19.1	7.3	1	13	3	2.1	0.09	0.08	0.06	0.01	1.86	8.4	91.8
25-Aug-2022	D/S	18.6	7.1	1	11	1	3.1	0.11	0.09	0.03	0.01	3.12	8.5	90.6
7-Sep-2022	D/S	18.1	7.01	1	16	1	3.8	0.06	0.03	0.03	0.02	3.6	8.4	87.7
28-Sep-2022	D/S	13.8	7.4	1	2	2	3.1	0.05	0.04	0.02	0.01	3.11	9.5	93.3
19-Oct-2022	D/S	13.7	7.27	1	8	3	3.6	0.05	0.07	0.03	0.01	3.52	9.5	91.4
26-Oct-2022	D/S	13.8	7.46	1	11	2	2.9	0.06	0.21	0.03	0.01	2.8	9.8	96.1
17-Nov-2022	D/S	9.6	7.67	1	5	2	2.7	0.04	0.06	0.02	0.01	2.64	10.6	95.5
30-Nov-2022	D/S	9.2	7.46	1	10	4	2.22	0.06	0.18	0.03	0.01	2.1	10.9	94
7-Dec-2022	D/S	9.1	7.39	1	5	1	2.1	0.05	0.19	0.03	0.02	1.98	10.4	89.8
14-Dec-2022	D/S	5.5	7.25	1	14	4	2.22	0.06	0.19	0.03	0.02	2.18	11.4	90.8
Mean		12.996	9.323	1.000	13.077	2.731	3.348	0.074	0.1054	0.0400	0.014	2.792	10.091	94.272
95%ile		19.340	8.100	1.000	24.000	6.250	4.600	0.133	0.210	0.085	0.028	3.580	11.640	98.280

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.