

Annual Environmental Report

2022



Banagher

D0141-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 BANAGHER WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - BANAGHER WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - BANAGHER WWTP
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR BANAGHER WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO BANAGHER WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 DRINKING WATER ABSTRACTION POINT RISK ASSESSMENT
- 5.2 PRIORITY SUBSTANCES ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0141-01, Banagher, in Offaly in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

There were no capital works, significant changes or operational changes undertaken in 2022.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Banagher WWTP with a Plant Capacity PE of 3000, the treatment type is 2 - Secondary treatment.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF2500D0141SW001	Banagher WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

There are no Licence Specific Reports included in this AER.

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 BANAGHER WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - BANAGHER WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
BOD, 5 days with Inhibition (Carbonaceous) mg/l	12	131	66
Total Nitrogen mg/l	2	34	32
Ammonia-Total (as N) mg/l	12	31	19
COD-Cr mg/l	12	390	166
Suspended Solids mg/l	12	176	73
ortho-Phosphate (as P) - unspecified mg/l	12	1.10	0.455
pH pH units	12	7.97	7.50
Total Phosphorus (as P) mg/l	2	2.22	2.17
Hydraulic Capacity	N/A	2636	1104

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2500D0141SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	13	N/A	N/A	23	Pass
Suspended Solids mg/l	35	88	N/A	13	N/A	N/A	3.21	Pass
BOD, 5 days with Inhibition (Carbonaceous) mg/l	25	50	N/A	13	N/A	N/A	1.54	Pass
pH pH units	6.00	9.00	N/A	13	N/A	N/A	7.55	Pass
Ammonia-Total (as N) mg/l	2.00	2.40	N/A	13	N/A	N/A	0.079	Pass
ortho-Phosphate (as P) - unspecified mg/l	1.00	1.20	N/A	13	N/A	N/A	0.028	Pass
Conductivity @20°C µS/cm	N/A	N/A	N/A	1	N/A	N/A	541	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Total Nitrogen mg/l	N/A	N/A	N/A	2	N/A	N/A	12	
Nitrate (as N) mg/l	N/A	N/A	N/A	1	N/A	N/A	4.00	
Nitrite (as N) mg/l	N/A	N/A	N/A	1	N/A	N/A	0.083	
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	2	N/A	N/A	0.077	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2500D0141SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	200520, 215835	RS25S012000	No	No	No	No	Moderate
Downstream	199853, 215797	RS25S012010	No	Yes	No	No	Moderate

Where the receiving water body is not a river or where the data is not in EDEN – the Ambient data will be appended.

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ortho-Phosphate concentration downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it is or is not caused by the WWTP.

Other causes of deterioration in water quality in the area are unknown.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - BANAGHER WWTP

2.1.4.1 Treatment Efficiency Report - Banagher WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	32862	1615	95
COD	74676	11436	85
TN	21629	8863	59
TP	1486	58	96
cBOD	29804	775	97

Note: The above data is based on sample results for the number of dates reported.

2.1.4.2 Treatment Capacity Report Summary - Banagher WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Banagher WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	1688
DWF to the Treatment Plant (m ³ /day)	563
Current Hydraulic Loading - annual max (m ³ /day)	2636
Average Hydraulic loading to the Treatment Plant (m ³ /day)	1104
Organic Capacity (PE) - As Constructed	3000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	2373
Organic Capacity (PE) - Remaining	627
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - BANAGHER WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2022.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Uncontrolled release	Network Infrastructure	1	No	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	2
Number of Incidents reported to the EPA via EDEN in 2022	2
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m ³)	Monitoring Status
SW003	200249 215725	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW002	200015 215725	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m ³)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0141-SIP:01	Improvement works to control spillages from the waste water works and ensure compliance with Condition 5.6	C	31/12/2020	No	Works Completed		No works deemed necessary as the SWOs already meet DoEHLG criteria.
D0141-SIP:02	Improvement works to ensure compliance with Condition 1.7	C	31/12/2015	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Drinking Water Abstraction Point Risk Assessment	Yes	2015	No
Priority Substances Assessment	Yes	2016	No

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 24/02/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Ambient monitoring summary

Banagher Ambient Monitoring Summary 2022

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)			
			Bathing Water	Drinking Water	FWPM	Shellfish
Upstream Monitoring Point	200520, 215835	RS25S012000	No	No	No	No
Downstream Monitoring Point	199853, 215797	RS25S012010	No	Yes	No	No

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Current WFD Status	cBOD (mean) mg/l	o-Phosphate (as P) (mean) mg/l	Ammonia (as N) (mean) mg/l
Upstream Monitoring Point	Moderate	1.025	0.0116	0.034
Downstream Monitoring Point	Moderate	0.885	0.0129	0.025
<i>Difference</i>		<i>-0.140</i>	<i>0.0013</i>	<i>-0.009</i>
EQS		1.500	0.035	0.065
% of EQS		-9.302%	3.736%	-13.216%

Banagher Ambient Monitoring Data 2022

		Temperature	pH	BOD	COD	Suspended solids	Total Nitrogen as N	Total Phosphorus as P	Total Ammonia as N	Ortho-Phosphate as P	Nitrite as N	Nitrate as N	Conductivity	DO	DO
Station	Sample Date	Degrees C	pH units	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	µS/m	mg/l	% sat
Banagher U/S	19/01/2022	4	7.4	1.4	<20	<2.5			0.059	0.009				12	97
Banagher U/S	03/02/2022	4.2	7.99	< 1	23	4	1.5	0.05	0.036	0.01				12	100.1
Banagher U/S	07/04/2022	10.6	7.88	< 1	< 20	3			< 0.02	0.009				11.64	109.7
Banagher U/S	26/04/2022	10.1	8.08	< 1	22	< 2	< 2	< 0.1	< 0.02	< 0.02	< 0.015	< 1		12.3	112.1
Banagher U/S	27/04/2022	9.8	8.24	1.4	60	< 2	2.9	< 0.1	< 0.02	< 0.02	< 0.015	1		12.4	112.4
Banagher U/S	09/05/2022	12	8.4	< 1	24	< 2			0.031	< 0.02			423	12.2	100.2
Banagher U/S	18/05/2022	10.2	8.38	< 1	< 20	< 2	< 2	< 0.1	0.021	< 0.02	< 0.015	< 1	385	12.4	100.5
Banagher U/S	25/05/2022	12.1	8.37	< 1	21	< 2	< 2	< 0.1	0.031	< 0.02	< 0.015	< 1	406	12.8	102.2
Banagher U/S	08/06/2022	15.7	8.3	< 1	< 20	2.5			0.072	< 0.006				10.99	112.5
Banagher U/S	13/07/2022	18.4	8.21	< 1	25	3			0.032	0.009				11.05	100.5
Banagher U/S	10/08/2022		8.34	1.3	< 20	< 2.5	0.759	< 0.05	< 0.02	< 0.006	0.004	0.331	385		
Banagher U/S	28/09/2022	13.6	8.17	< 1	< 20	< 2.5			0.027	0.008				9.23	92
Banagher U/S	12/10/2022	12.2	8.1	1.9	33	4.5			0.034	0.015				9.91	93.2
Banagher U/S	17/11/2022	8.5	7.5	< 1	48	< 2.5			0.096	0.02				9.11	80.5
Banagher U/S	01/12/2022	4.1	8.18	2.3	37	< 2			< 0.02	< 0.02				11	100.1
	Mean	10.393	8.103	1.025	25.190	2.170	1.567	0.061	0.034	0.012	0.009	0.690	399.750	11.359	100.929
	95%ile	16.645	8.386	2.020	51.600	4.150	2.550	0.071	0.079	0.017	0.011	0.941	420.450	12.540	112.435

		Temperature	pH	BOD	COD	Suspended solids	Total Nitrogen as N	Total Phosphorus as P	Total Ammonia as N	Ortho-Phosphate as P	Nitrite as N	Nitrate as N	Conductivity	DO mg/l	DO
Station	Sample Date	Degrees C	pH units	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	µS/m	mg/l	% sat
Banagher D/S	19/01/2022	4.1	7.77	<1	30	<2.5			<0.02	0.014				12.6	99
Banagher D/S	03/02/2022	4.6	8.01	1.5	29	5	1.7	0.06	0.06	0.016				12.3	105.1
Banagher D/S	07/04/2022	10.5	7.95	<1	22	10			0.032	0.013				11.65	109.8
Banagher D/S	26/04/2022	10.1	8.21	<1	<20	<2	<2	<0.1	<0.02	<0.02	<0.015	<1		12.4	112.3
Banagher D/S	27/04/2022	9.2	8.27	1	61	<2	2.5	<0.1	<0.02	<0.02	<0.015	1.1		12.4	112.2
Banagher D/S	09/05/2022	12.7	8.28	<1	24	<2			0.026	<0.02			422	12.44	100.1
Banagher D/S	18/05/2022	10.3	8.31	<1	<20	<2	<2	<0.1	0.031	<0.02	<0.015	1	391	12.6	100.4
Banagher D/S	25/05/2022	12.7	8.38	<1	27	<2	<2	<0.1	<0.02	<0.02	<0.015	<1	410	12.5	102.1
Banagher D/S	08/06/2022	16	8.3	<1	<20	3			0.026	0.007				10.79	111.3
Banagher D/S	13/07/2022	18.4	8.26	<1	30	<2.5			0.027	0.008				10.93	99.5
Banagher D/S	10/08/2022		8.45	1.2	<20	<2.5	1.02	<0.05	<0.02	<0.006	0.005	0.561	399		
Banagher D/S	28/09/2022	13.6	8.13	<1	<20	<2.5			0.028	0.006				9.53	95
Banagher D/S	12/10/2022	12.2	8.1	1.8	35	3			0.04	0.016				9.88	94.3
Banagher D/S	17/11/2022	8.6	7.4	<1	39	<2.5			<0.02	0.014				9.2	82.1
Banagher D/S	01/12/2022	4.1	8.08	<1	31	<2			0.026	0.024				11.3	100.7
	Mean	10.507	8.127	0.885	26.581	2.555	1.577	0.063	0.025	0.013	0.009	0.815	405.500	11.466	101.707
	95%ile	16.720	8.398	1.575	44.500	6.250	2.260	0.071	0.045	0.018	0.011	1.075	419.600	12.600	112.230

Note: Where the concentration in the result is less than the limit of detection (LOD), a value of LOD/sqrt(2) was used in calculating the mean and 95%ile concentrations.