

# Annual Environmental Report

2018



Mohill

D0277-01

## **TABLE OF CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER**

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
  - 1.2.1 MOHILL WWTP
- 1.3 ELV OVERVIEW
  - 1.3.1 MOHILL WWTP
- 1.4 SLUDGE REMOVAL

### **2 MONITORING REPORTS SUMMARY**

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
  - 2.1.1 INFLUENT MONITORING SUMMARY - MOHILL WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
  - 2.2.1 EFFLUENT MONITORING SUMMARY - MOHILL WWTP
- 2.3 AMBIENT MONITORING SUMMARY
  - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - MOHILL WWTP
  - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - MOHILL WWTP

### **3 OPERATIONAL REPORTS SUMMARY**

- 3.1 TREATMENT EFFICIENCY REPORT
  - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - MOHILL WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
  - 3.4.1 SUMMARY OF INCIDENTS
  - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

### **4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION
  - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

**5 LICENCE SPECIFIC REPORTS**

**6 CERTIFICATION AND SIGN OFF**

6.1 SUMMARY OF AER CONTENTS

6.2 DECLARATION BY IRISH WATER

**7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0277-01, Mohill, in Leitrim in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

## 1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
There is no Licence Specific Reports included in the AER.	

## 1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant MOHILL WWTP with a Plant Capacity PE of 2000. The treatment process includes the following:

### 1.2.1 MOHILL WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	Yes	6 mm screen
Primary Treatment	No	
Secondary Treatment	Yes	Conventional Aeration
Nutrient Removal	Yes	Ferric Dosing
Tertiary Treatment	No	

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

### 1.3 ELV Overview

#### 1.3.1 MOHILL WWTP

Compliance Status	
Were all parameters compliant for MOHILL WWTP treatment plant	No
Where noncompliant see table 2.2.1 for details of parameters	

### 1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
MOHILL WWTP	Cake Sludge	48.28	Volume (m3)	14.27	Biocore, Ballivor, Co. Meath

#### Annual Statement of Measures

Works commenced on the decommissioning of the surface aerator and the installation of fine bubble diffusers. Work commenced on the upgrade of the final settlement tank. Work commenced on the decommissioning of the Return Activated Sludge/Waste Activated Sludge (RAS/WAS) mechanical lifting wheel and the installation of a RAS/WAS Pumping facility. Work has commenced on the construction of a new storm holding tank. Works are underway on the associated mechanical and electrical works associated with the works mentioned above. This work is projected to be completed in quarter 2 2019.

## 2 MONITORING REPORTS SUMMARY

### 2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

#### 2.1.1 Influent Monitoring Summary - MOHILL WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
Suspended Solids mg/l	22	192	51.44
Total Nitrogen mg/l	1	6	6
COD-Cr mg/l	22	388	99.76
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	22	147	40.3
Total Phosphorus (as P) mg/l	1	0.64	0.64
Hydraulic Capacity	0	2643	855.97

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable

#### Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2.

## 2.2 Discharges from the agglomeration

### 2.2.1 Effluent Monitoring Summary - MOHILL WWTP

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Visual Inspection Descriptive	0	0	0	8	0	0	0	Pass
COD-Cr mg/l	0	0	0	22	0	0	23.05	Pass
Total Nitrogen mg/l	0	0	0	1	0	0	4.9	Pass
Odour Descriptive	0	0	0	22	0	0	0	Pass
Appearance (on Sampling) Descriptive	0	0	0	14	0	0	0	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	2	4	0	22	16	3	2.59	Fail
ortho-Phosphate (as P) - unspecified mg/l	0.1	0.2	0	22	10	5	0.14	Fail
Ammonia-Total (as N) mg/l	0.2	0.4	0	22	13	9	0.83	Fail

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Conductivity 20 C $\mu$ S/cm	0	0	0	22	0	0	48.93	Pass
Total Phosphorus (as P) mg/l	0	0	0	1	0	0	0.37	Pass
pH pH units	0	0	0	22	0	0	7.61	Pass
Temperature °C	25	0	0	22	0	0	0.79	Pass
Suspended Solids mg/l	10	25	0	22	4	0	7.27	Fail

Notes:

1- This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 - For parameters where a mean ELV applies

#### Cause of Exceedance(s):

Inadequate WWTP infrastructure which requires an upgrade.

#### Significance of Results:

The WWTP was non-compliant with the ELV's set in the Wastewater Discharge Licence. There were 16 exceedances in relation to the BOD parameter ELV, 3 of which were above the Condition 2 ELV. There were 13 exceedances of the Ammonia parameter ELV, 9 of which were above the Condition 2 ELV. There were 10 exceedances of the ortho-Phosphate parameter, 5 of which were above the Condition 2 ELV. There were 4 exceedances of the Suspended Solids parameter ELV, none of which were above the Condition 2 ELV. The impact on the receiving water is assessed further in section 2.3.



## 2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

### 2.3.1 Ambient Monitoring Report Summary - MOHILL WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
<b>Upstream</b>	208893, 297529	TPEFF1700D0277SW001	No	No	No	No	Poor
<b>Downstream</b>	209051, 296218	TPEFF1700D0277SW001	No	No	No	No	Poor

### 2.3.2 Ambient Monitoring Parameter Summary - MOHILL WWTP

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>Total Nitrogen mg/l</b>	RS26R020006	1.4	RS26R020057	4.81		
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	RS26R020006	0.08	RS26R020057	0.19	0.075	142.9
<b>Temperature °C</b>	RS26R020006	11.41	RS26R020057	11.81		
<b>Dissolved Oxygen % O2</b>	RS26R020006	90.91	RS26R020057	83.56		

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>pH pH units</b>	RS26R020006	7.54	RS26R020057	7.5		
<b>Suspended Solids mg/l</b>	RS26R020006	3	RS26R020057	21		
<b>Ammonia-Total (as N) mg/l</b>	RS26R020006	0.08	RS26R020057	0.34	0.14	185.9
<b>BOD - 5 days (Total) mg/l</b>	RS26R020006	1.23	RS26R020057	3.33	2.6	80.8
<b>Dissolved Oxygen mg/l</b>	RS26R020006	9.9	RS26R020057	9.13		

#### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The discharge from the works maybe giving rise to a breach of EQS in the receiving water regardless of status.

The parameters which exceeded the EQS and may be causing an impact are: Ammonia, BOD and ortho-Phosphate.

Any other known impacts: Agriculture - stream not fenced to prevent access by cattle. Drainage works also being carried out and clearing of vegetation from the banks of the stream leading to soil being washed into the stream.

### 3 OPERATIONAL REPORTS SUMMARY

#### 3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

##### 3.1.1 Treatment Efficiency Report Summary - MOHILL WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
<b>COD</b>	34280.53	7672.95	77.62	
<b>SS</b>	17676.7	2419.97	86.31	
<b>cBOD</b>	13848.59	861.77	93.78	
<b>TN</b>	4971.3	4083.15	17.87	
<b>TP</b>	530.27	308.32	41.86	

Note: The above data is based on sample results for the number of dates reported

### 3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

MOHILL WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	400
DWF to the Treatment Plant (m <sup>3</sup> /day)	400
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	2643
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	855.97
Organic Capacity (PE) - As Constructed	2000
Organic Capacity (PE) - Collected Load (peak week)	1254
Organic Capacity (PE) - Remaining	746
Will the capacity be exceeded in the next three years? (Yes/No)	No

### 3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
2	Blocked Sewer	0	2

### 3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance. A summary of reported incidents is included below.

#### 3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Non-compliance	WWTP upgrade required to meet ELV	19	Yes	No
Non-compliance	WWTP upgrade required to meet ELV	1	Yes	Yes
Spillage	Other	1	No	Yes

#### 3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	21
Number of Incidents reported to the EPA via EDEN in 2018	21
Explanation of any discrepancies between the two numbers above	N/A

### 3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below.

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

**No Appendix Included**

#### 4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m3)	Monitoring Status
SW002	209065, 296378	Yes	Medium	Meeting	-	-	Not Monitored
SW003	209084, 296634	Yes	Medium	Meeting	-	-	Not Monitored
SW004	209003, 296933	No	Medium	Meeting	-	-	Not Monitored
SW005	209055, 296673	No	Medium	Meeting	-	-	Not Monitored

#### 4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m <sup>3</sup> )?	Unknown
Is each SWO identified as non meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / charges to Schedule C3 and A4 under Condition 1.7?	Yes

### 4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

#### 4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>Any works that may be required under Condition 5.6</b>	C	22/12/2015	Yes	Not Started	As indicated by the LA, unknown completion date	The improvement programme will be reviewed by Irish Water for works required to comply with the license condition on a prioritised basis.



A summary of the status of any improvements identified by under Condition 5.2 is included below.

#### 4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
<b>D0277-IP:35</b>	<p>Works commenced on the decommissioning of the surface aerator and the installation of fine bubble diffusers. Work commenced on the upgrade of the final settlement tank.</p> <p>Work commenced on the decommissioning of the Return Activated Sludge/Waste Activated Sludge (RAS/WAS) mechanical lifting wheel and the installation of a RAS/WAS Pumping facility. Work has commenced on the construction of a new storm holding tank. Works are underway on the associated mechanical and electrical works associated with the works mentioned above. This work is projected to be completed in quarter 2 2019.</p>	Improved Operational Control	9/30/2019	

#### 4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

### 5.1 Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER (e.g. Appendix X).
<b>There is no Licence Specific Report Required in this AER Annual Review.</b>				

## 6 CERTIFICATION AND SIGN OFF

### 6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:

Date: 29/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Acting Head of Environmental Regulation.

## **7 APPENDIX**

There are no Appendices included.