

# Annual Environmental Report

2018



Ballycanew and Environs

D0402-01

## **TABLE OF CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER**

- 1.1 LICENCE SPECIFIC REPORTING INCLUDED IN AER
- 1.2 TREATMENT TYPE
  - 1.2.1 BALLYCANEW AND ENVIRONS WWTP
- 1.3 ELV OVERVIEW
  - 1.3.1 BALLYCANEW AND ENVIRONS WWTP
- 1.4 SLUDGE REMOVAL

### **2 MONITORING REPORTS SUMMARY**

- 2.1 SUMMARY REPORT ON MONTHLY INFLUENT MONITORING
  - 2.1.1 INFLUENT MONITORING SUMMARY - BALLYCANEW AND ENVIRONS WWTP
- 2.2 DISCHARGES FROM THE AGGLOMERATION
  - 2.2.1 EFFLUENT MONITORING SUMMARY - BALLYCANEW AND ENVIRONS WWTP
- 2.3 AMBIENT MONITORING SUMMARY
  - 2.3.1 AMBIENT MONITORING REPORT SUMMARY - BALLYCANEW AND ENVIRONS WWTP
  - 2.3.2 AMBIENT MONITORING PARAMETER MEAN (MG/L) - BALLYCANEW AND ENVIRONS WWTP

### **3 OPERATIONAL REPORTS SUMMARY**

- 3.1 TREATMENT EFFICIENCY REPORT
  - 3.1.1 TREATMENT EFFICIENCY REPORT SUMMARY - BALLYCANEW AND ENVIRONS WWTP
- 3.2 TREATMENT CAPACITY REPORT SUMMARY
- 3.3 COMPLAINTS SUMMARY
- 3.4 REPORTED INCIDENTS SUMMARY
  - 3.4.1 SUMMARY OF INCIDENTS
  - 3.4.2 SUMMARY OF OVERALL INCIDENTS
- 3.5 SLUDGE / OTHER INPUTS TO THE WWTP

### **4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION
  - 4.1.2 INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

- 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
- 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
- 4.2.3 SEWER INTEGRITY RISK ASSESSMENT SUMMARY

**5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

**6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS
- 6.2 DECLARATION BY IRISH WATER

**7 APPENDIX**

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2018 AER

This Annual Environmental Report has been prepared for D0402-01, Ballycanew and Environs, in Wexford in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports are included as an appendix to the AER as follows:

## 1.1 Licence specific reporting included in AER

Assessment / Report	Included in AER
There are no licence specific reports included	

## 1.2 Treatment Type

The agglomeration is served by a wastewater treatment plant Ballycanew and Environs WWTP with a Plant Capacity PE of 100. The treatment process includes the following:

### 1.2.1 Ballycanew and Environs WWTP

Treatment type	Yes / No	Details
Preliminary Treatment	No	
Primary Treatment	Yes	Primary settlement Tank
Secondary Treatment	No	
Nutrient Removal	No	
Tertiary Treatment	No	

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.2 Discharges from the agglomeration.

### 1.3 ELV Overview

#### 1.3.1 Ballycanew and Environs WWTP

Compliance Status	
Were all parameters compliant for Ballycanew and Environs WWTP treatment plant	No
Where noncompliant see table 2.2.1 for details of parameters	

### 1.4 Sludge Removal

The amount of sludge removed from the wastewater treatment plant is shown below along with the transported destination of the sludge from the treatment plant.

Treatment Plant	Sludge type	Quantity	Unit	% Dry Solids	Destination
Ballycanew and Environs WWTP	Liquid Sludge	393.64	Volume (m3)	1.68	Sludge Facility Courtown WWTP

#### Annual Statement of Measures

There were no onsite capital works or significant changes in 2018

## 2 MONITORING REPORTS SUMMARY

### 2.1 Summary report on monthly influent monitoring

A summary of influent monitoring for the treatment plant is presented in below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

#### 2.1.1 Influent Monitoring Summary - Ballycanew and Environs WWTP

Parameters	Number of Samples	Annual Max	Annual Mean
Total Nitrogen	2	79.1	79.1
COD-Cr	5	569	419.44
BOD, 5 days with Inhibition (Carbonaceous BOD)	5	312	227.95
Total Phosphorus (as P)	2	8	8
Suspended Solids	2	131	126
Hydraulic Capacity	0	426.6	213.3

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 3.5 if applicable

#### Significance of Results:

The annual mean hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity as detailed further in Section 3.2.

## 2.2 Discharges from the agglomeration

### 2.2.1 Effluent Monitoring Summary - Ballycanew and Environs WWTP

Parameter	Interim % reduction from influent concentration	Number of sample results	Annual Mean	Overall Compliance (Pass/Fail)
<b>Suspended Solids</b>	50	5	69.03	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous BOD)</b>	20	5	181.29	Pass

Note: the licence ELV commencement date is 31/12/2019. Interim ELVs are in place (as per Table 2.2.1) until such time.

#### Cause of Exceedance(s):

WWTP upgrade required

#### Significance of Results:

The WWTP is non-compliant with the ELV's set in the Wastewater Discharge Licence. Percentage reduction was not achieved.

## 2.3 Ambient monitoring summary

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

### 2.3.1 Ambient Monitoring Report Summary - Ballycanew and Environs WWTP

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	315239, 151942	TPEFF3300D0402SW001	No	No	No	No	Moderate
Downstream	315080, 152288	TPEFF3300D0402SW001	No	No	No	No	Moderate

### 2.3.2 Ambient Monitoring Parameter Summary - Ballycanew and Environs WWTP

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Kjeldahl Nitrogen	RS11O010400	0.45	RS11O010500	2.41		
Suspended Solids	RS11O010400	3.75	RS11O010500	5.75		
BOD, 5 days with Inhibition (Carbonaceous BOD)	RS11O010400	1.3	RS11O010500	3.2	2.6	73.1
Total Nitrogen	RS11O010400	4.3	RS11O010500	6.05		
Total Phosphorus (as P)	RS11O010400	0.05	RS11O010500	0.23		
Ammonia-Total (as N)	RS11O010400	0.06	RS11O010500	0.26	0.15	142.4
Total Hardness (as CaCO <sub>3</sub> )	RS11O010400	122.6	RS11O010500	120.56		
BOD - 5 days (Total)	RS11O010400	1.75	RS11O010500	2.23	2.6	18.4
pH	RS11O010400	7.77	RS11O010500	7.81		



<b>Chloride</b>	RS11O010400	28.16	RS11O010500	27.58		
<b>COD-Cr</b>	RS11O010400	9.5	RS11O010500	20.5		
<b>Nitrate (as N)</b>	RS11O010400	2.8	RS11O010500	2.84		
<b>True Colour</b>	RS11O010400	29.2	RS11O010500	28.78		
<b>Temperature</b>	RS11O010400	13.73	RS11O010500	13.26		
<b>Nitrite (as N)</b>	RS11O010400	17.4	RS11O010500	42.88		
<b>Alkalinity-total (as CaCO3)</b>	RS11O010400	93	RS11O010500	95.11		
<b>Dissolved Oxygen</b>	RS11O010400	53.42	RS11O010500	52.63		
<b>Total Oxidised Nitrogen (as N)</b>	RS11O010400	3.07	RS11O010500	3.05		
<b>ortho-Phosphate (as P) - unspecified</b>	RS11O010400	0.04	RS11O010500	0.09	0.08	62.2
<b>Conductivity @25°C</b>	RS11O010400	327.8	RS11O010500	323.44		

#### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The discharge from the works may be giving rise to a breach of EQS in the receiving water regardless of status.

The parameters which exceeded the EQS and may be causing an are: Ammonia, Ortho-P and BOD.

Any other know impacts: Agricultural activity and onsite WWTP in upstream catchment

### 3 OPERATIONAL REPORTS SUMMARY

#### 3.1 Treatment Efficiency Report

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

##### 3.1.1 Treatment Efficiency Report Summary - Ballycanew and Environs WWTP

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)	Comment
<b>COD</b>	32620.9	22179.83	32.01	
<b>TP</b>	621.96	761.9	-22.5	
<b>SS</b>	9795.87	5368.85	45.19	
<b>cBOD</b>	17728.1	14099.06	20.47	
<b>TN</b>	6149.63	6903.76	-12.26	

Note: The above data is based on sample results for the number of dates reported

#### 3.2 Treatment Capacity Report Summary

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Ballycanew and Environs WWTP	
<b>Peak Hydraulic Capacity (m3/day) - As Constructed</b>	135

<b>DWF to the Treatment Plant (m3/day)</b>	22.5
<b>Current Hydraulic Loading - annual max (m3/day)</b>	426.6
<b>Average Hydraulic loading to the Treatment Plant (m3/day)</b>	213.3
<b>Organic Capacity (PE) - As Constructed</b>	100
<b>Organic Capacity (PE) - Collected Load (peak week)</b>	667
<b>Organic Capacity (PE) - Remaining</b>	0
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	Yes

### 3.3 Complaints Summary

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
1	Blocked Sewer	0	1

### 3.4 Reported Incidents Summary

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.4.1 Summary of Incidents

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Non-compliance	WWTP upgrade required to meet ELV	5	Yes	No

### 3.4.2 Summary of Overall Incidents

Question	Answer
Number of Incidents in 2018	5
Number of Incidents reported to the EPA via EDEN in 2018	5
Explanation of any discrepancies between the two numbers above	

### 3.5 Sludge / Other inputs to the WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)? <sup>3</sup>	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? <sup>2</sup> (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 Storm Water Overflow Identification and Inspection Report

A summary of the operation of the storm water overflows and their significance where known is included below:

**No Appendix Included**

#### 4.1.1 SWO Identification

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2018 (No. of events)	Total volume discharged in 2018 (m3)	Monitoring Status
SW02 (D0402)	N/A	No	Unknown	Not yet Assessed	Unknown	Unknown	Not Monitored

#### 4.1.2 Inspection Summary Report

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as non meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	No
Have the EPA been advised of any additional SWOs/ charges to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 Report on progress made and proposals being developed to meet the improvement programme requirements.

### 4.2.1 Specified Improvement Programme Summary

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>Construct a new WWTP to comply with ELVs specified in Schedule A</b>	C	31/12/2019	No	Not Started	<i>The improvement programme will be reviewed by Irish Water to assess the works required to comply with the licence condition on a prioritised basis</i>	

A summary of the status of any improvements identified by under Condition 5.2 is included below.

### 4.2.2 Improvement Programme Summary

Improvement Identifier	Improvement Description	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### 4.2.3 Sewer Integrity Risk Assessment

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table".

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER (e.g. Appendix X).
<b>Priority Substances Assessment</b>	Yes	2015	No	

## 6 CERTIFICATION AND SIGN OFF

### 6.1 Summary of AER Contents

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	Yes
List reason e.g. additional SWO identified	Additional SWO identified
Is there a need to request/advise the EPA of any modifications to the existing WWDL?	No
List reason e.g. changes to monitoring requirements	
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No



I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 28/03/2019

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

## 7 APPENDIX

In the appendix include all the detailed or site specific reports that are relevant to the AER. Reports omitted from previous AERs should also be appended here.

There are no Appendices included