



- Legend:**
- Proposed Landline
 - Proposed Incoming Raw Sewage Main
 - Proposed Outgoing Final Effluent Main
 - Proposed Chamber
 - Proposed Tank
 - Proposed Building
 - Proposed Sludge Plant
 - Proposed Handstanding and Plant
 - Proposed Access (within site perimeter)

- Notes:**
1. This drawing is not to be scaled. Figured dimensions only to be taken.
 2. The Process type and arrangement shown requires confirmation by outline design.
 3. 33kV Power line passes through the proposed land boundary. It is assumed that the power line to be re-routed around site boundary.
 4. All earthworks shall be at a maximum slope of 1V : 2H.
 5. All tanks shall be covered with GRP clam shell covers.
 6. All drawings to be checked by the Contractor on Site.
 7. Engineer to be informed by the Contractor of any discrepancies before any work commences.
 8. All levels shown relate to Ordnance Survey datum at Malin Head, the geographic coordinate system is to Irish Transverse Mercator (ITM).

© OpenStreetMap (and) contributors, CC-BY-SA
 Service Layer: basemap, terrain; © Ordnance Survey Ireland
 World Ocean Base: GSI, Esri, Garmin, NaturalView



U	11/10/2023	Final	LB	SMG	SMG	JB
Rev	Date	Purpose of revision	Drawn	Checked	Rev'd	App'd

Jacobs



Client: **Uisce Éireann**

Project: **Greater Dublin Drainage Project**

Drawing Title: **Figure 4.1 - Zonal Arrangement at the Proposed Wastewater Treatment Plant**

Drawing Status: **Final**

Scale @A3: **DO NOT SCALE**

Jacobs No: **321120AP**

Filepath: **321120AP-EIARAddendum-0401**

Drawing No: **321120AP-EIARAddendum-0401**

This drawing is not to be used in whole or part other than for the intended purpose and project as defined on this drawing. Refer to the contract for full terms and conditions.

